

UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6092117

Bend LaPine Schools 1410 SE Wilson Ave. Bend, OR 97702	Project: No Project Project #: RE Jewell Elementary Client Contact: Mike Tiller	Date Reported: 10/25/16 Date Received: 09/21/16 11:40 Sampled By: Adam Seile
--	---	--

Method: EPA 200.8

Matrix: Drinking Water

	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
6092117-01	Sample Location: #1 Prep Sink									
Lead		1030	ND	mg/L	0.002	0.02	09/16/16 05:35	09/23/16	DJP	
Copper			0.018	mg/L	0.010	1.3	09/16/16 05:35	09/23/16	DJP	
6092117-02	Sample Location: #2 Bottle Filler									
Lead		1030	ND	mg/L	0.002	0.02	09/16/16 05:36	09/23/16	DJP	
Copper			0.072	mg/L	0.010	1.3	09/16/16 05:36	09/23/16	DJP	
6092117-03	Sample Location: #3 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	09/16/16 05:36	09/23/16	DJP	
Copper			0.074	mg/L	0.010	1.3	09/16/16 05:36	09/23/16	DJP	
6092117-04	Sample Location: #4 Drinking Fountain									
Lead		1030	0.002	mg/L	0.002	0.02	09/16/16 05:37	09/23/16	DJP	
Copper			0.042	mg/L	0.010	1.3	09/16/16 05:37	09/23/16	DJP	
6092117-05	Sample Location: #5 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	09/16/16 05:39	09/23/16	DJP	
Copper			ND	mg/L	0.010	1.3	09/16/16 05:39	09/23/16	DJP	
6092117-06	Sample Location: #6 Drinking Fountain									
Lead		1030	0.002	mg/L	0.002	0.02	09/16/16 05:40	09/23/16	DJP	
Copper			ND	mg/L	0.010	1.3	09/16/16 05:40	09/23/16	DJP	
6092117-07	Sample Location: #7 Drinking Fountain									
Lead		1030	0.002	mg/L	0.002	0.02	09/16/16 05:43	09/23/16	DJP	
Copper			ND	mg/L	0.010	1.3	09/16/16 05:43	09/23/16	DJP	
6092117-08	Sample Location: #8 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	09/16/16 05:44	09/23/16	DJP	
Copper			ND	mg/L	0.010	1.3	09/16/16 05:44	09/23/16	DJP	
6092117-09	Sample Location: #9 Drinking Fountain									


UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager

Revision Report



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6092117

Method: EPA 200.8

Matrix: Drinking Water

	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
		1030	ND	mg/L	0.002	0.02	09/16/16 05:45	09/23/16	DJP	
			ND	mg/L	0.010	1.3	09/16/16 05:45	09/23/16	DJP	
6092117-10	Sample Location: #10 Drinking Fountain									
		1030	ND	mg/L	0.002	0.02	09/16/16 05:46	09/23/16	DJP	
			ND	mg/L	0.010	1.3	09/16/16 05:46	09/23/16	DJP	
6092117-11	Sample Location: #11 Drinking Fountain									
		1030	0.002	mg/L	0.002	0.02	09/16/16 05:47	09/23/16	DJP	
			ND	mg/L	0.010	1.3	09/16/16 05:47	09/23/16	DJP	
6092117-12	Sample Location: #12 Drinking Fountain									
		1030	0.002	mg/L	0.002	0.02	09/16/16 05:47	09/23/16	DJP	
			ND	mg/L	0.010	1.3	09/16/16 05:47	09/23/16	DJP	
6092117-13	Sample Location: #13 Drinking Fountain									
		1030	0.002	mg/L	0.002	0.02	09/16/16 05:50	09/23/16	DJP	
			0.010	mg/L	0.010	1.3	09/16/16 05:50	09/23/16	DJP	
6092117-14	Sample Location: #14 Drinking Fountain									
		1030	ND	mg/L	0.002	0.02	09/16/16 05:51	09/23/16	DJP	
			0.011	mg/L	0.010	1.3	09/16/16 05:51	09/23/16	DJP	
6092117-15	Sample Location: #15 Drinking Fountain									
		1030	0.004	mg/L	0.002	0.02	09/16/16 05:50	09/23/16	DJP	
			ND	mg/L	0.010	1.3	09/16/16 05:50	09/23/16	DJP	
6092117-16	Sample Location: #16 Drinking Fountain									
		1030	0.002	mg/L	0.002	0.02	09/16/16 05:53	09/23/16	DJP	
			ND	mg/L	0.010	1.3	09/16/16 05:53	09/23/16	DJP	
6092117-17	Sample Location: #17 Drinking Fountain									
		1030	0.002	mg/L	0.002	0.02	09/16/16 05:54	09/23/16	DJP	
			ND	mg/L	0.010	1.3	09/16/16 05:54	09/23/16	DJP	
6092117-18	Sample Location: #18 Drinking Fountain									
		1030	0.002	mg/L	0.002	0.02	09/16/16 05:55	09/23/16	DJP	
			ND	mg/L	0.010	1.3	09/16/16 05:55	09/23/16	DJP	
6092117-19	Sample Location: #19 Drinking Fountain									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager

Revision Report



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: http://ChemLab.cc
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6092117

Method: EPA 200.8

Matrix: Drinking Water

	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead		1030	ND	mg/L	0.002	0.02	09/16/16 05:56	09/23/16	DJP	
Copper			0.029	mg/L	0.010	1.3	09/16/16 05:56	09/23/16	DJP	
6092117-20	Sample Location: #20 Bottle Filler									
Lead		1030	ND	mg/L	0.002	0.02	09/16/16 05:57	09/23/16	DJP	
Copper			0.031	mg/L	0.010	1.3	09/16/16 05:57	09/23/16	DJP	
6092117-21	Sample Location: #21 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	09/16/16 05:58	09/23/16	DJP	
Copper			0.032	mg/L	0.010	1.3	09/16/16 05:58	09/23/16	DJP	
6092117-22	Sample Location: #22 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	09/16/16 05:59	09/23/16	DJP	
Copper			0.091	mg/L	0.010	1.3	09/16/16 05:59	09/23/16	DJP	
6092117-23	Sample Location: #23 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	09/16/16 06:00	09/23/16	DJP	
Copper			0.084	mg/L	0.010	1.3	09/16/16 06:00	09/23/16	DJP	
6092117-24	Sample Location: #24 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	09/16/16 06:02	09/23/16	DJP	
Copper			0.080	mg/L	0.010	1.3	09/16/16 06:02	09/23/16	DJP	
6092117-25	Sample Location: #25 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	09/16/16 06:03	09/23/16	DJP	
Copper			0.078	mg/L	0.010	1.3	09/16/16 06:03	09/23/16	DJP	
6092117-26	Sample Location: #26 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	09/16/16 06:03	09/23/16	DJP	
Copper			0.079	mg/L	0.010	1.3	09/16/16 06:03	09/23/16	DJP	
6092117-27	Sample Location: #27 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	09/16/16 06:04	09/23/16	DJP	
Copper			0.081	mg/L	0.010	1.3	09/16/16 06:04	09/23/16	DJP	
6092117-28	Sample Location: #28 Drinking Fountain									
Lead		1030	0.003	mg/L	0.002	0.02	09/16/16 06:06	09/23/16	DJP	
Copper			0.014	mg/L	0.010	1.3	09/16/16 06:06	09/23/16	DJP	
6092117-29	Sample Location: #29 Drinking Fountain									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager

Revision Report



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6092117

Method: EPA 200.8

Matrix: Drinking Water

	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead		1030	ND	mg/L	0.002	0.02	09/16/16 06:07	09/23/16	DJP	
Copper			ND	mg/L	0.010	1.3	09/16/16 06:07	09/23/16	DJP	
6092117-30	Sample Location: #30 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	09/16/16 06:10	09/23/16	DJP	
Copper			ND	mg/L	0.010	1.3	09/16/16 06:10	09/23/16	DJP	
6092117-31	Sample Location: #31 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	09/16/16 06:10	09/29/16	DJP	
Copper			ND	mg/L	0.010	1.3	09/16/16 06:10	09/29/16	DJP	
6092117-32	Sample Location: #32 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	09/16/16 06:12	09/29/16	DJP	
Copper			ND	mg/L	0.010	1.3	09/16/16 06:12	09/29/16	DJP	
6092117-33	Sample Location: #33 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	09/16/16 06:15	09/29/16	DJP	
Copper			ND	mg/L	0.010	1.3	09/16/16 06:15	09/29/16	DJP	
6092117-34	Sample Location: #34 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	09/16/16 06:13	09/29/16	DJP	
Copper			ND	mg/L	0.010	1.3	09/16/16 06:13	09/29/16	DJP	
6092117-35	Sample Location: #35 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	09/16/16 06:16	09/29/16	DJP	
Copper			ND	mg/L	0.010	1.3	09/16/16 06:16	09/29/16	DJP	
6092117-36	Sample Location: #36 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	09/16/16 06:17	09/29/16	DJP	
Copper			ND	mg/L	0.010	1.3	09/16/16 06:17	09/29/16	DJP	


UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager

Revision Report



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: <http://ChemLab.cc>
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6092117

Qualifiers and Definitions

Rev1	Revised Report 10-25-16. Corrected Project Number per Client's Request
DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the MRL (minimum reporting limit)
NA	Not Applicable
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
MRL	Minimum Reporting Limit
MDL	Minimum Detection Limit
MCL	Maximum Contamination Level
(‡)	ORELAP Accredited Analyte
(~)	Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager

Revision Report