

UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6101918

Bend LaPine Schools 1410 SE Wilson Ave. Bend, OR 97702	Project: 2016 Lead Testing Project #: High Lakes Elementary Client Contact: Mike Tiller	Date Reported: 10/28/16 Date Received: 10/19/16 08:55 Sampled By: Jon Layton
--	---	--

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
6101918-01	Sample Location: #1 Bottle Filler									
	Lead	1030	ND	mg/L	0.002	0.02	10/14/16 04:10	10/20/16	DJP	
	Copper		0.055	mg/L	0.010	1.3	10/14/16 04:10	10/20/16	DJP	
6101918-02	Sample Location: #2 Drinking Fountain									
	Lead	1030	ND	mg/L	0.002	0.02	10/14/16 04:11	10/20/16	DJP	
	Copper		0.064	mg/L	0.010	1.3	10/14/16 04:11	10/20/16	DJP	
6101918-03	Sample Location: #3 Drinking Fountain									
	Lead	1030	ND	mg/L	0.002	0.02	10/14/16 04:11	10/20/16	DJP	
	Copper		0.063	mg/L	0.010	1.3	10/14/16 04:11	10/20/16	DJP	
6101918-04	Sample Location: #4 Prep Sink									
	Lead	1030	ND	mg/L	0.002	0.02	10/14/16 04:17	10/20/16	DJP	
	Copper		0.081	mg/L	0.010	1.3	10/14/16 04:17	10/20/16	DJP	
6101918-05	Sample Location: #5 Drinking Fountain									
	Lead	1030	ND	mg/L	0.002	0.02	10/14/16 04:18	10/20/16	DJP	
	Copper		0.088	mg/L	0.010	1.3	10/14/16 04:18	10/20/16	DJP	
6101918-06	Sample Location: #6 Drinking Fountain									
	Lead	1030	ND	mg/L	0.002	0.02	10/14/16 04:19	10/20/16	DJP	
	Copper		0.091	mg/L	0.010	1.3	10/14/16 04:19	10/20/16	DJP	
6101918-07	Sample Location: #7 Drinking Fountain									
	Lead	1030	ND	mg/L	0.002	0.02	10/14/16 04:20	10/20/16	DJP	
	Copper		0.141	mg/L	0.010	1.3	10/14/16 04:20	10/20/16	DJP	
6101918-08	Sample Location: #8 Drinking Fountain									
	Lead	1030	ND	mg/L	0.002	0.02	10/14/16 04:24	10/20/16	DJP	
	Copper		0.094	mg/L	0.010	1.3	10/14/16 04:24	10/20/16	DJP	
6101918-09	Sample Location: #9 Drinking Fountain									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6101918

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
		1030	ND	mg/L	0.002	0.02	10/14/16 04:25	10/20/16	DJP	
			0.100	mg/L	0.010	1.3	10/14/16 04:25	10/20/16	DJP	
6101918-10	Sample Location: #10 Drinking Fountain									
		1030	ND	mg/L	0.002	0.02	10/14/16 04:27	10/20/16	DJP	
			0.095	mg/L	0.010	1.3	10/14/16 04:27	10/20/16	DJP	
6101918-11	Sample Location: #11 Drinking Fountain									
		1030	ND	mg/L	0.002	0.02	10/14/16 04:29	10/20/16	DJP	
			0.092	mg/L	0.010	1.3	10/14/16 04:29	10/20/16	DJP	
6101918-12	Sample Location: #12 Drinking Fountain									
		1030	ND	mg/L	0.002	0.02	10/14/16 04:30	10/20/16	DJP	
			0.097	mg/L	0.010	1.3	10/14/16 04:30	10/20/16	DJP	
6101918-13	Sample Location: #13 Drinking Fountain									
		1030	ND	mg/L	0.002	0.02	10/14/16 04:32	10/20/16	DJP	
			0.104	mg/L	0.010	1.3	10/14/16 04:32	10/20/16	DJP	
6101918-14	Sample Location: #14 Drinking Fountain									
		1030	ND	mg/L	0.002	0.02	10/14/16 04:33	10/20/16	DJP	
			0.101	mg/L	0.010	1.3	10/14/16 04:33	10/20/16	DJP	
6101918-15	Sample Location: #15 Drinking Fountain									
		1030	ND	mg/L	0.002	0.02	10/14/16 04:36	10/20/16	DJP	
			0.108	mg/L	0.010	1.3	10/14/16 04:36	10/20/16	DJP	
6101918-16	Sample Location: #16 Drinking Fountain									
		1030	ND	mg/L	0.002	0.02	10/14/16 04:37	10/20/16	DJP	
			0.088	mg/L	0.010	1.3	10/14/16 04:37	10/20/16	DJP	
6101918-17	Sample Location: #17 Drinking Fountain									
		1030	ND	mg/L	0.002	0.02	10/14/16 04:38	10/24/16	DJP	
			0.088	mg/L	0.010	1.3	10/14/16 04:38	10/24/16	DJP	
6101918-18	Sample Location: #18 Drinking Fountain									
		1030	ND	mg/L	0.002	0.02	10/14/16 04:39	10/24/16	DJP	
			0.091	mg/L	0.010	1.3	10/14/16 04:39	10/24/16	DJP	
6101918-19	Sample Location: #19 Drinking Fountain									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: http://ChemLab.cc
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6101918

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead		1030	ND	mg/L	0.002	0.02	10/14/16 04:42	10/24/16	DJP	
Copper			0.086	mg/L	0.010	1.3	10/14/16 04:42	10/24/16	DJP	
6101918-20	Sample Location: #20 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	10/14/16 04:43	10/24/16	DJP	
Copper			0.083	mg/L	0.010	1.3	10/14/16 04:43	10/24/16	DJP	
6101918-21	Sample Location: #21 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	10/14/16 04:44	10/24/16	DJP	
Copper			0.084	mg/L	0.010	1.3	10/14/16 04:44	10/24/16	DJP	
6101918-22	Sample Location: #22 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	10/14/16 04:47	10/24/16	DJP	
Copper			0.087	mg/L	0.010	1.3	10/14/16 04:47	10/24/16	DJP	
6101918-23	Sample Location: #23 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	10/14/16 04:49	10/24/16	DJP	
Copper			0.088	mg/L	0.010	1.3	10/14/16 04:49	10/24/16	DJP	
6101918-24	Sample Location: #24 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	10/14/16 04:50	10/24/16	DJP	
Copper			0.090	mg/L	0.010	1.3	10/14/16 04:50	10/24/16	DJP	
6101918-25	Sample Location: #25 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	10/14/16 04:51	10/24/16	DJP	
Copper			0.093	mg/L	0.010	1.3	10/14/16 04:51	10/24/16	DJP	
6101918-26	Sample Location: #26 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	10/14/16 04:53	10/24/16	DJP	
Copper			0.084	mg/L	0.010	1.3	10/14/16 04:53	10/24/16	DJP	
6101918-27	Sample Location: #27 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	10/14/16 04:54	10/24/16	DJP	
Copper			0.089	mg/L	0.010	1.3	10/14/16 04:54	10/24/16	DJP	
6101918-28	Sample Location: #28 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	10/14/16 04:55	10/24/16	DJP	
Copper			0.090	mg/L	0.010	1.3	10/14/16 04:55	10/24/16	DJP	
6101918-29	Sample Location: #29 Drinking Fountain									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: http://ChemLab.cc
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6101918

Method: EPA 200.8

Matrix: Drinking Water

	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
		1030	ND	mg/L	0.002	0.02	10/14/16 04:56	10/24/16	DJP	
			0.102	mg/L	0.010	1.3	10/14/16 04:56	10/24/16	DJP	
6101918-30	Sample Location: #30 Drinking Fountain									
		1030	ND	mg/L	0.002	0.02	10/14/16 04:58	10/24/16	DJP	
			0.090	mg/L	0.010	1.3	10/14/16 04:58	10/24/16	DJP	
6101918-31	Sample Location: #31 Drinking Fountain									
		1030	ND	mg/L	0.002	0.02	10/14/16 04:59	10/24/16	DJP	
			0.091	mg/L	0.010	1.3	10/14/16 04:59	10/24/16	DJP	
6101918-32	Sample Location: #32 Drinking Fountain									
		1030	ND	mg/L	0.002	0.02	10/14/16 05:00	10/24/16	DJP	
			0.091	mg/L	0.010	1.3	10/14/16 05:00	10/24/16	DJP	
6101918-33	Sample Location: #33 Drinking Fountain									
		1030	ND	mg/L	0.002	0.02	10/14/16 05:03	10/24/16	DJP	
			0.088	mg/L	0.010	1.3	10/14/16 05:03	10/24/16	DJP	
6101918-34	Sample Location: #34 Drinking Fountain									
		1030	ND	mg/L	0.002	0.02	10/14/16 05:04	10/24/16	DJP	
			0.089	mg/L	0.010	1.3	10/14/16 05:04	10/24/16	DJP	
6101918-35	Sample Location: #35 Drinking Fountain									
		1030	ND	mg/L	0.002	0.02	10/14/16 05:05	10/24/16	DJP	
			0.089	mg/L	0.010	1.3	10/14/16 05:05	10/24/16	DJP	
6101918-36	Sample Location: #36 Drinking Fountain									
		1030	ND	mg/L	0.002	0.02	10/14/16 05:06	10/24/16	DJP	
			0.094	mg/L	0.010	1.3	10/14/16 05:06	10/24/16	DJP	
6101918-37	Sample Location: #37 Drinking Fountain									
		1030	ND	mg/L	0.002	0.02	10/14/16 05:06	10/24/16	DJP	
			0.092	mg/L	0.010	1.3	10/14/16 05:06	10/24/16	DJP	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: <http://ChemLab.cc>
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6101918

Qualifiers and Definitions

DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the MRL (minimum reporting limit)
NA	Not Applicable
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
MRL	Minimum Reporting Limit
MDL	Minimum Detection Limit
MCL	Maximum Contamination Level
(‡)	ORELAP Accredited Analyte
(~)	Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

Tom Williams, Laboratory Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.