

Radon test result report for:  
**PACIFIC CREST MS**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
7994753	A103	2018-02-12 @ 6:00 am	2018-02-14 @ 7:00 am	0.6 ± 0.2	2018-02-15
7994754	A104	2018-02-12 @ 6:00 am	2018-02-14 @ 7:00 am	0.9 ± 0.2	2018-02-15
7994755	A105	2018-02-12 @ 6:00 am	2018-02-14 @ 7:00 am	0.8 ± 0.2	2018-02-15
7994756	A105	2018-02-12 @ 6:00 am	2018-02-14 @ 7:00 am	0.6 ± 0.2	2018-02-15
7994757	A108	2018-02-12 @ 6:00 am	2018-02-14 @ 7:00 am	0.7 ± 0.2	2018-02-15
7994758	A113	2018-02-12 @ 6:00 am	2018-02-14 @ 7:00 am	0.6 ± 0.2	2018-02-15
7994759	A114	2018-02-12 @ 6:00 am	2018-02-14 @ 7:00 am	0.7 ± 0.2	2018-02-15
7994760	A115	2018-02-12 @ 6:00 am	2018-02-14 @ 7:00 am	0.6 ± 0.2	2018-02-15
7994761	A117	2018-02-12 @ 6:00 am	2018-02-14 @ 7:00 am	0.6 ± 0.2	2018-02-15
7994762	A118	2018-02-12 @ 6:00 am	2018-02-14 @ 7:00 am	< 0.3	2018-02-15
7994763	A121	2018-02-12 @ 6:00 am	2018-02-14 @ 7:00 am	0.6 ± 0.2	2018-02-15
7994764	A123	2018-02-12 @ 6:00 am	2018-02-14 @ 7:00 am	< 0.3	2018-02-15
7994765	A125	2018-02-12 @ 6:00 am	2018-02-14 @ 7:00 am	0.5 ± 0.2	2018-02-15
7994766	A125	2018-02-12 @ 6:00 am	2018-02-14 @ 7:00 am	< 0.3	2018-02-15
7994767	A126	2018-02-12 @ 6:00 am	2018-02-14 @ 7:00 am	0.6 ± 0.2	2018-02-15
7994768	A127	2018-02-12 @ 6:00 am	2018-02-14 @ 7:00 am	0.6 ± 0.2	2018-02-15
7994769	A128	2018-02-12 @ 6:00 am	2018-02-14 @ 7:00 am	0.6 ± 0.2	2018-02-15
7994770	A129	2018-02-12 @ 6:00 am	2018-02-14 @ 7:00 am	< 0.3	2018-02-15
7994401	B104	2018-02-12 @ 6:00 am	2018-02-14 @ 7:00 am	0.6 ± 0.2	2018-02-15
7994402	B106	2018-02-12 @ 6:00 am	2018-02-14 @ 7:00 am	0.8 ± 0.2	2018-02-15
7994403	B109	2018-02-12 @ 6:00 am	2018-02-14 @ 7:00 am	1.1 ± 0.2	2018-02-15
7994404	B110	2018-02-12 @ 6:00 am	2018-02-14 @ 7:00 am	0.7 ± 0.2	2018-02-15
7994405	B121	2018-02-12 @ 6:00 am	2018-02-14 @ 7:00 am	0.7 ± 0.2	2018-02-15
7994406	B125	2018-02-12 @ 6:00 am	2018-02-14 @ 7:00 am	1.2 ± 0.2	2018-02-15
7994407	B127	2018-02-12 @ 6:00 am	2018-02-14 @ 7:00 am	0.9 ± 0.2	2018-02-15
7994408	B128	2018-02-12 @ 6:00 am	2018-02-14 @ 7:00 am	0.7 ± 0.2	2018-02-15
7994409	B131	2018-02-12 @ 6:00 am	2018-02-14 @ 7:00 am	< 0.3	2018-02-15
7994410	B131	2018-02-12 @ 6:00 am	2018-02-14 @ 7:00 am	0.7 ± 0.2	2018-02-15
7994411	B132	2018-02-12 @ 6:00 am	2018-02-14 @ 7:00 am	0.9 ± 0.2	2018-02-15
7994412	B136	2018-02-12 @ 6:00 am	2018-02-14 @ 7:00 am	0.8 ± 0.2	2018-02-15
7994413	B139	2018-02-12 @ 6:00 am	2018-02-14 @ 7:00 am	0.8 ± 0.2	2018-02-15
7994414	B140	2018-02-12 @ 6:00 am	2018-02-14 @ 7:00 am	0.9 ± 0.2	2018-02-15
7994415	B142	2018-02-12 @ 6:00 am	2018-02-14 @ 7:00 am	0.6 ± 0.2	2018-02-15
7994416	C108	2018-02-12 @ 6:00 am	2018-02-14 @ 7:00 am	1.0 ± 0.2	2018-02-15
7994417	C110	2018-02-12 @ 6:00 am	2018-02-14 @ 7:00 am	0.8 ± 0.2	2018-02-15
7994420	C113 (GYM)	2018-02-12 @ 6:00 am	2018-02-14 @ 7:00 am	0.8 ± 0.2	2018-02-15
7994421	C113 (GYM)	2018-02-12 @ 6:00 am	2018-02-14 @ 7:00 am	0.7 ± 0.2	2018-02-15

Radon test result report for:  
**PACIFIC CREST MS**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
7994422	C113 (GYM)	2018-02-12 @ 6:00 am	2018-02-14 @ 7:00 am	0.6 ± 0.2	2018-02-15
7994419	C113 (GYM)	2018-02-12 @ 6:00 am	2018-02-14 @ 7:00 am	0.8 ± 0.2	2018-02-15
7994771	D105	2018-02-12 @ 6:00 am	2018-02-14 @ 7:00 am	1.4 ± 0.2	2018-02-15
7994772	D106	2018-02-12 @ 6:00 am	2018-02-14 @ 7:00 am	0.6 ± 0.2	2018-02-15
7994773	D107	2018-02-12 @ 6:00 am	2018-02-14 @ 7:00 am	0.6 ± 0.2	2018-02-15
7994774	D108	2018-02-12 @ 6:00 am	2018-02-14 @ 7:00 am	0.8 ± 0.2	2018-02-15
7994776	D109	2018-02-12 @ 6:00 am	2018-02-14 @ 7:00 am	0.7 ± 0.2	2018-02-15
7994775	D109	2018-02-12 @ 6:00 am	2018-02-14 @ 7:00 am	0.9 ± 0.2	2018-02-15
7994777	D113	2018-02-12 @ 6:00 am	2018-02-14 @ 7:00 am	0.8 ± 0.2	2018-02-15
7994778	D115	2018-02-12 @ 6:00 am	2018-02-14 @ 7:00 am	0.8 ± 0.2	2018-02-15
7994779	D116	2018-02-12 @ 6:00 am	2018-02-14 @ 7:00 am	0.9 ± 0.2	2018-02-15
7994782	D119	2018-02-12 @ 6:00 am	2018-02-14 @ 7:00 am	< 0.3	2018-02-15
7994781	D119	2018-02-12 @ 6:00 am	2018-02-14 @ 7:00 am	0.7 ± 0.2	2018-02-15
7994783	D121	2018-02-12 @ 6:00 am	2018-02-14 @ 7:00 am	< 0.3	2018-02-15
7994784	E100	2018-02-12 @ 6:00 am	2018-02-14 @ 7:00 am	0.7 ± 0.2	2018-02-15
7994785	E102	2018-02-12 @ 6:00 am	2018-02-14 @ 7:00 am	0.6 ± 0.2	2018-02-15
7994786	E102	2018-02-12 @ 6:00 am	2018-02-14 @ 7:00 am	0.8 ± 0.2	2018-02-15
7994787	E106	2018-02-12 @ 6:00 am	2018-02-14 @ 7:00 am	0.8 ± 0.2	2018-02-15
7994788	E107	2018-02-12 @ 6:00 am	2018-02-14 @ 7:00 am	0.6 ± 0.2	2018-02-15
7994789	E108	2018-02-12 @ 6:00 am	2018-02-14 @ 7:00 am	< 0.3	2018-02-15
7994791	E110	2018-02-12 @ 6:00 am	2018-02-14 @ 7:00 am	0.6 ± 0.2	2018-02-15
7994792	E113	2018-02-12 @ 6:00 am	2018-02-14 @ 7:00 am	0.8 ± 0.2	2018-02-15
7994793	E115	2018-02-12 @ 6:00 am	2018-02-14 @ 7:00 am	0.6 ± 0.2	2018-02-15
7994794	E116	2018-02-12 @ 6:00 am	2018-02-14 @ 7:00 am	< 0.3	2018-02-15
7994795	E117	2018-02-12 @ 6:00 am	2018-02-14 @ 7:00 am	0.9 ± 0.2	2018-02-15
7994796	E119	2018-02-12 @ 6:00 am	2018-02-14 @ 7:00 am	0.9 ± 0.2	2018-02-15
7994800	E122	2018-02-12 @ 6:00 am	2018-02-14 @ 7:00 am	< 0.3	2018-02-15
7994799	E122	2018-02-12 @ 6:00 am	2018-02-14 @ 7:00 am	< 0.3	2018-02-15
7994751	MAIN OFFICE	2018-02-12 @ 6:00 am	2018-02-14 @ 7:00 am	0.8 ± 0.2	2018-02-15
7994798	YOGA ROOM	2018-02-12 @ 6:00 am	2018-02-14 @ 7:00 am	0.7 ± 0.2	2018-02-15