



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: http://ChemLab.cc
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6102116

Bend LaPine Schools	Project: 2016 Lead Testing	Date Reported: 10/28/16
1410 SE Wilson Ave.	Project #: KPOV Radio	Date Sampled: 10/20/16 06:12
Bend, OR 97702	Client Contact: Mike Tiller	Date Received: 10/21/16 12:30
		Sampled By: Tom Everest

Sample Location: #1 Faucet

URC Sample #: 6102116-01

Matrix: Drinking Water

Metals


Analyte	Method	Code	Result	Units	MRL	MCL	Prepared	Analyzed	Analyst	Qualifier
Copper	EPA 200.8		0.015	mg/L	0.010	1.3	10/27/16	10/27/16	DJP	
Lead	EPA 200.8	1030	0.002	mg/L	0.002	0.02	10/27/16	10/27/16	DJP	

UMPQUA Research Company/MC

Tom Williams, Laboratory Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: <http://ChemLab.cc>
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6102116

Qualifiers and Definitions

DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the MRL (minimum reporting limit)
NA	Not Applicable
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
MRL	Minimum Reporting Limit
MDL	Minimum Detection Limit
MCL	Maximum Contamination Level
(‡)	ORELAP Accredited Analyte
(~)	Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

Tom Williams, Laboratory Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.