



# UMPQUA Research Company

626 NE Division St. - P.O. Box 609  
 Myrtle Creek, Oregon 97457  
 (541) 863-5201 Fax: (541) 863-6199  
 E-mail: Lab@URCmail.net  
 Internet: http://ChemLab.cc  
 ORELAP ID# OR100031

## ANALYSIS REPORT

URC # 6092109

Bend LaPine Schools 1410 SE Wilson Ave. Bend, OR 97702	Project: No Project Project #: Bear Creek Elementary Client Contact: Mike Tiller	Date Reported: 10/07/16 Date Received: 09/21/16 11:40 Sampled By: Adam Seile
--	--	--

Method: EPA 200.8

Matrix: Drinking Water

	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
6092109-01	Sample Location: #1 Drinking Fountain									
	Lead	1030	0.002	mg/L	0.002	0.02	09/16/16 04:19	09/22/16	DJP	
	Copper		ND	mg/L	0.010	1.3	09/16/16 04:19	09/22/16	DJP	
6092109-02	Sample Location: #2 Drinking Fountain									
	Lead	1030	ND	mg/L	0.002	0.02	09/16/16 04:20	09/22/16	DJP	
	Copper		0.047	mg/L	0.010	1.3	09/16/16 04:20	09/22/16	DJP	
6092109-03	Sample Location: #3 Drinking Fountain									
	Lead	1030	ND	mg/L	0.002	0.02	09/16/16 04:23	09/22/16	DJP	
	Copper		0.040	mg/L	0.010	1.3	09/16/16 04:23	09/22/16	DJP	
6092109-04	Sample Location: #4 Drinking Fountain									
	Lead	1030	ND	mg/L	0.002	0.02	09/16/16 04:29	09/22/16	DJP	
	Copper		0.090	mg/L	0.010	1.3	09/16/16 04:29	09/22/16	DJP	
6092109-05	Sample Location: #5 Drinking Fountain									
	Lead	1030	ND	mg/L	0.002	0.02	09/16/16 04:30	09/22/16	DJP	
	Copper		0.049	mg/L	0.010	1.3	09/16/16 04:30	09/22/16	DJP	
6092109-06	Sample Location: #6 Drinking Fountain									
	Lead	1030	ND	mg/L	0.002	0.02	09/16/16 04:31	09/22/16	DJP	
	Copper		0.054	mg/L	0.010	1.3	09/16/16 04:31	09/22/16	DJP	
6092109-07	Sample Location: #7 Drinking Fountain									
	Lead	1030	ND	mg/L	0.002	0.02	09/16/16 04:32	09/22/16	DJP	
	Copper		0.053	mg/L	0.010	1.3	09/16/16 04:32	09/22/16	DJP	
6092109-08	Sample Location: #8 Drinking Fountain									
	Lead	1030	ND	mg/L	0.002	0.02	09/16/16 04:34	09/22/16	DJP	
	Copper		0.017	mg/L	0.010	1.3	09/16/16 04:34	09/22/16	DJP	
6092109-09	Sample Location: #9 Drinking Fountain									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



# UMPQUA Research Company

626 NE Division St. - P.O. Box 609  
 Myrtle Creek, Oregon 97457  
 (541) 863-5201 Fax: (541) 863-6199  
 E-mail: Lab@URCmail.net  
 Internet: http://ChemLab.cc  
 ORELAP ID# OR100031

## ANALYSIS REPORT

URC # 6092109

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead		1030	ND	mg/L	0.002	0.02	09/16/16 04:35	09/22/16	DJP	
Copper			0.064	mg/L	0.010	1.3	09/16/16 04:35	09/22/16	DJP	
6092109-10	Sample Location: #10 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	09/16/16 04:37	09/22/16	DJP	
Copper			0.064	mg/L	0.010	1.3	09/16/16 04:37	09/22/16	DJP	
6092109-11	Sample Location: #11 Prep Sink									
Lead		1030	0.004	mg/L	0.002	0.02	09/16/16 04:38	09/22/16	DJP	
Copper			0.097	mg/L	0.010	1.3	09/16/16 04:38	09/22/16	DJP	
6092109-12	Sample Location: #12 Bottle Filler									
Lead		1030	ND	mg/L	0.002	0.02	09/16/16 04:44	09/22/16	DJP	
Copper			0.054	mg/L	0.010	1.3	09/16/16 04:44	09/22/16	DJP	
6092109-13	Sample Location: #13 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	09/16/16 04:44	09/22/16	DJP	
Copper			0.059	mg/L	0.010	1.3	09/16/16 04:44	09/22/16	DJP	
6092109-14	Sample Location: #14 Drinking Fountain									
Lead		1030	0.002	mg/L	0.002	0.02	09/16/16 04:47	09/22/16	DJP	
Copper			0.018	mg/L	0.010	1.3	09/16/16 04:47	09/22/16	DJP	
6092109-15	Sample Location: #15 Drinking Fountain									
Lead		1030	0.004	mg/L	0.002	0.02	09/16/16 04:50	09/22/16	DJP	
Copper			ND	mg/L	0.010	1.3	09/16/16 04:50	09/22/16	DJP	
6092109-16	Sample Location: #16 Drinking Fountain									
Lead		1030	0.002	mg/L	0.002	0.02	09/16/16 04:52	09/22/16	DJP	
Copper			ND	mg/L	0.010	1.3	09/16/16 04:52	09/22/16	DJP	
6092109-17	Sample Location: #17 Drinking Fountain									
Lead		1030	0.003	mg/L	0.002	0.02	09/16/16 04:55	09/22/16	DJP	
Copper			ND	mg/L	0.010	1.3	09/16/16 04:55	09/22/16	DJP	
6092109-18	Sample Location: #18 Drinking Fountain									
Lead		1030	0.002	mg/L	0.002	0.02	09/16/16 04:56	09/22/16	DJP	
Copper			ND	mg/L	0.010	1.3	09/16/16 04:56	09/22/16	DJP	
6092109-19	Sample Location: #19 Drinking Fountain									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



# UMPQUA Research Company

626 NE Division St. - P.O. Box 609  
 Myrtle Creek, Oregon 97457  
 (541) 863-5201 Fax: (541) 863-6199  
 E-mail: Lab@URCmail.net  
 Internet: http://ChemLab.cc  
 ORELAP ID# OR100031

## ANALYSIS REPORT

URC # 6092109

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead		1030	0.002	mg/L	0.002	0.02	09/16/16 04:58	09/22/16	DJP	
Copper			ND	mg/L	0.010	1.3	09/16/16 04:58	09/22/16	DJP	
6092109-20	Sample Location: #20 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	09/16/16 05:01	09/22/16	DJP	
Copper			0.044	mg/L	0.010	1.3	09/16/16 05:01	09/22/16	DJP	
6092109-21	Sample Location: #21 Drinking Fountain									
Lead		1030	0.003	mg/L	0.002	0.02	09/16/16 05:02	09/22/16	DJP	
Copper			0.026	mg/L	0.010	1.3	09/16/16 05:02	09/22/16	DJP	
6092109-22	Sample Location: #22 Drinking Fountain									
Lead		1030	0.003	mg/L	0.002	0.02	09/16/16 05:04	09/22/16	DJP	
Copper			ND	mg/L	0.010	1.3	09/16/16 05:04	09/22/16	DJP	
6092109-23	Sample Location: #23 Drinking Fountain									
Lead		1030	0.002	mg/L	0.002	0.02	09/16/16 05:05	09/22/16	DJP	
Copper			ND	mg/L	0.010	1.3	09/16/16 05:05	09/22/16	DJP	
6092109-24	Sample Location: #24 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	09/16/16 05:05	09/22/16	DJP	
Copper			0.186	mg/L	0.010	1.3	09/16/16 05:05	09/22/16	DJP	
6092109-25	Sample Location: #25 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	09/16/16 05:06	09/22/16	DJP	
Copper			0.195	mg/L	0.010	1.3	09/16/16 05:06	09/22/16	DJP	
6092109-26	Sample Location: #26 Drinking Fountain									
Lead		1030	0.002	mg/L	0.002	0.02	09/16/16 05:10	09/22/16	DJP	
Copper			0.014	mg/L	0.010	1.3	09/16/16 05:10	09/22/16	DJP	
6092109-27	Sample Location: #27 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	09/16/16 05:11	09/22/16	DJP	
Copper			ND	mg/L	0.010	1.3	09/16/16 05:11	09/22/16	DJP	
6092109-28	Sample Location: #28 Drinking Fountain									
Lead		1030	0.002	mg/L	0.002	0.02	09/16/16 05:13	09/22/16	DJP	
Copper			ND	mg/L	0.010	1.3	09/16/16 05:13	09/22/16	DJP	
6092109-29	Sample Location: #29 Drinking Fountain									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



**UMPQUA Research Company**

626 NE Division St. - P.O. Box 609  
Myrtle Creek, Oregon 97457  
(541) 863-5201 Fax: (541) 863-6199  
E-mail: Lab@URCmail.net  
Internet: http://ChemLab.cc  
ORELAP ID# OR100031

**ANALYSIS REPORT**

**URC # 6092109**

Method: EPA 200.8

Matrix: Drinking Water

	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead		1030	0.003	mg/L	0.002	0.02	09/16/16 05:13	09/22/16	DJP	
Copper			ND	mg/L	0.010	1.3	09/16/16 05:13	09/22/16	DJP	
6092109-30	Sample Location: #30 Drinking Fountain									
Lead		1030	0.002	mg/L	0.002	0.02	09/16/16 05:13	09/22/16	DJP	
Copper			ND	mg/L	0.010	1.3	09/16/16 05:13	09/22/16	DJP	
6092109-31	Sample Location: #31 Drinking Fountain									
Lead		1030	0.002	mg/L	0.002	0.02	09/16/16 05:15	09/22/16	DJP	
Copper			ND	mg/L	0.010	1.3	09/16/16 05:15	09/22/16	DJP	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



## UMPQUA Research Company

626 NE Division St. - P.O. Box 609  
Myrtle Creek, Oregon 97457  
(541) 863-5201 Fax: (541) 863-6199  
E-mail: Lab@URCmail.net  
Internet: <http://ChemLab.cc>  
ORELAP ID# OR100031

## ANALYSIS REPORT

URC # 6092109

### Qualifiers and Definitions

DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the MRL (minimum reporting limit)
NA	Not Applicable
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
MRL	Minimum Reporting Limit
MDL	Minimum Detection Limit
MCL	Maximum Contamination Level
(‡)	ORELAP Accredited Analyte
(~)	Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

Tom Williams, Laboratory Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.