



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# ORI00031

ANALYSIS REPORT

URC # 6100427

Bend LaPine Schools 1410 SE Wilson Ave. Bend, OR 97702	Project: No Project Project #: Juniper Elementary 1300 NE Norton, Bend Or Client Contact: Bend LaPine Schools	Date Reported: 10/12/16 Date Received: 10/04/16 12:00 Sampled By: Kevin Aas
--------------------------------------------------------------	------------------------------------------------------------------------------------------------------------------------	-----------------------------------------------------------------------------------

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
6100427-01	Sample Location: #1 Prep Sink									
	Lead	1030	ND	mg/L	0.002	0.02	09/30/16 05:01	10/05/16	DJP	
	Copper		0.082	mg/L	0.010	1.3	09/30/16 05:01	10/05/16	DJP	
6100427-02	Sample Location: #2 Bottle Filler									
	Lead	1030	ND	mg/L	0.002	0.02	09/30/16 05:02	10/05/16	DJP	
	Copper		0.074	mg/L	0.010	1.3	09/30/16 05:02	10/05/16	DJP	
6100427-03	Sample Location: #3 Drinking Fountain									
	Lead	1030	ND	mg/L	0.002	0.02	09/30/16 05:02	10/05/16	DJP	
	Copper		0.100	mg/L	0.010	1.3	09/30/16 05:02	10/05/16	DJP	
6100427-04	Sample Location: #4 Drinking Fountain									
	Lead	1030	ND	mg/L	0.002	0.02	09/30/16 05:04	10/05/16	DJP	
	Copper		0.260	mg/L	0.010	1.3	09/30/16 05:04	10/05/16	DJP	
6100427-05	Sample Location: #5 Drinking Fountain									
	Lead	1030	ND	mg/L	0.002	0.02	09/30/16 05:04	10/05/16	DJP	
	Copper		0.228	mg/L	0.010	1.3	09/30/16 05:04	10/05/16	DJP	
6100427-06	Sample Location: #6 Drinking Fountain									
	Lead	1030	ND	mg/L	0.002	0.02	09/30/16 05:06	10/05/16	DJP	
	Copper		0.241	mg/L	0.010	1.3	09/30/16 05:06	10/05/16	DJP	
6100427-07	Sample Location: #7 Drinking Fountain									
	Lead	1030	ND	mg/L	0.002	0.02	09/30/16 05:09	10/05/16	DJP	
	Copper		0.152	mg/L	0.010	1.3	09/30/16 05:09	10/05/16	DJP	
6100427-08	Sample Location: #8 Faucet									
	Lead	1030	ND	mg/L	0.002	0.02	09/30/16 05:11	10/05/16	DJP	
	Copper		0.178	mg/L	0.010	1.3	09/30/16 05:11	10/05/16	DJP	
6100427-09	Sample Location: #9 Drinking Fountain									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6100427

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead		1030	ND	mg/L	0.002	0.02	09/30/16 05:12	10/05/16	DJP	
Copper			0.125	mg/L	0.010	1.3	09/30/16 05:12	10/05/16	DJP	
6100427-10	Sample Location: #10 Drinking Fountain									
Lead		1030	0.002	mg/L	0.002	0.02	09/30/16 05:13	10/05/16	DJP	
Copper			0.089	mg/L	0.010	1.3	09/30/16 05:13	10/05/16	DJP	
6100427-11	Sample Location: #11 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	09/30/16 05:14	10/05/16	DJP	
Copper			0.135	mg/L	0.010	1.3	09/30/16 05:14	10/05/16	DJP	
6100427-12	Sample Location: #12 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	09/30/16 05:15	10/05/16	DJP	
Copper			0.159	mg/L	0.010	1.3	09/30/16 05:15	10/05/16	DJP	
6100427-13	Sample Location: #13 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	09/30/16 05:19	10/05/16	DJP	
Copper			0.144	mg/L	0.010	1.3	09/30/16 05:19	10/05/16	DJP	
6100427-14	Sample Location: #14 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	09/30/16 05:20	10/05/16	DJP	
Copper			0.155	mg/L	0.010	1.3	09/30/16 05:20	10/05/16	DJP	
6100427-15	Sample Location: #15 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	09/30/16 05:20	10/05/16	DJP	
Copper			0.117	mg/L	0.010	1.3	09/30/16 05:20	10/05/16	DJP	
6100427-16	Sample Location: #16 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	09/30/16 05:22	10/05/16	DJP	
Copper			0.160	mg/L	0.010	1.3	09/30/16 05:22	10/05/16	DJP	
6100427-17	Sample Location: #17 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	09/30/16 05:23	10/05/16	DJP	
Copper			0.144	mg/L	0.010	1.3	09/30/16 05:23	10/05/16	DJP	
6100427-18	Sample Location: #18 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	09/30/16 05:24	10/05/16	DJP	
Copper			0.134	mg/L	0.010	1.3	09/30/16 05:24	10/05/16	DJP	
6100427-19	Sample Location: #19 Drinking Fountain									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6100427

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead		1030	ND	mg/L	0.002	0.02	09/30/16 05:26	10/05/16	DJP	
Copper			0.120	mg/L	0.010	1.3	09/30/16 05:26	10/05/16	DJP	
6100427-20	Sample Location: #20 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	09/30/16 05:27	10/05/16	DJP	
Copper			0.120	mg/L	0.010	1.3	09/30/16 05:27	10/05/16	DJP	
6100427-21	Sample Location: #21 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	09/30/16 05:28	10/05/16	DJP	
Copper			0.115	mg/L	0.010	1.3	09/30/16 05:28	10/05/16	DJP	
6100427-22	Sample Location: #22 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	09/30/16 05:30	10/05/16	DJP	
Copper			0.183	mg/L	0.010	1.3	09/30/16 05:30	10/05/16	DJP	
6100427-23	Sample Location: #23 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	09/30/16 05:32	10/05/16	DJP	
Copper			0.123	mg/L	0.010	1.3	09/30/16 05:32	10/05/16	DJP	
6100427-24	Sample Location: #24 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	09/30/16 05:32	10/05/16	DJP	
Copper			0.129	mg/L	0.010	1.3	09/30/16 05:32	10/05/16	DJP	
6100427-25	Sample Location: #25 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	09/30/16 05:32	10/05/16	DJP	
Copper			0.158	mg/L	0.010	1.3	09/30/16 05:32	10/05/16	DJP	
6100427-26	Sample Location: #26 Drinking Fountain									
Lead		1030	0.002	mg/L	0.002	0.02	09/30/16 05:35	10/05/16	DJP	
Copper			0.115	mg/L	0.010	1.3	09/30/16 05:35	10/05/16	DJP	
6100427-27	Sample Location: #27 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	09/30/16 05:36	10/05/16	DJP	
Copper			0.133	mg/L	0.010	1.3	09/30/16 05:36	10/05/16	DJP	
6100427-28	Sample Location: #28 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	09/30/16 05:36	10/05/16	DJP	
Copper			0.110	mg/L	0.010	1.3	09/30/16 05:36	10/05/16	DJP	
6100427-29	Sample Location: #29 Drinking Fountain									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: http://ChemLab.cc
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6100427

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead		1030	ND	mg/L	0.002	0.02	09/30/16 05:38	10/05/16	DJP	
Copper			0.164	mg/L	0.010	1.3	09/30/16 05:38	10/05/16	DJP	
6100427-30	Sample Location: #30 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	09/30/16 05:40	10/05/16	DJP	
Copper			0.120	mg/L	0.010	1.3	09/30/16 05:40	10/05/16	DJP	
6100427-31	Sample Location: #31 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	09/30/16 05:41	10/05/16	DJP	
Copper			0.140	mg/L	0.010	1.3	09/30/16 05:41	10/05/16	DJP	
6100427-32	Sample Location: #32 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	09/30/16 05:42	10/05/16	DJP	
Copper			0.136	mg/L	0.010	1.3	09/30/16 05:42	10/05/16	DJP	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: <http://ChemLab.cc>
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6100427

Qualifiers and Definitions

DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the MRL (minimum reporting limit)
NA	Not Applicable
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
MRL	Minimum Reporting Limit
MDL	Minimum Detection Limit
MCL	Maximum Contamination Level
(‡)	ORELAP Accredited Analyte
(~)	Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager