



# UMPQUA Research Company

626 NE Division St. - P.O. Box 609  
 Myrtle Creek, Oregon 97457  
 (541) 863-5201 Fax: (541) 863-6199  
 E-mail: Lab@URCmail.net  
 Internet: http://ChemLab.cc  
 ORELAP ID# OR100031

## ANALYSIS REPORT

URC # 6100429

Bend LaPine Schools 1410 SE Wilson Ave. Bend, OR 97702	Project: No Project Project #: Pilot Butte Middle School 1501 NE Neff Rd, Bend Or Client Contact: Bend LaPine Schools	Date Reported: 10/12/16 Date Received: 10/04/16 12:00 Sampled By: Tom Everest
--	--	---

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
6100429-01	Sample Location: #1 Drinking Fountain									
	Lead	1030	ND	mg/L	0.002	0.02	09/29/16 04:51	10/06/16	DJP	
	Copper		0.069	mg/L	0.010	1.3	09/29/16 04:51	10/06/16	DJP	
6100429-02	Sample Location: #2 Bottle Filler									
	Lead	1030	ND	mg/L	0.002	0.02	09/29/16 04:51	10/06/16	DJP	
	Copper		0.080	mg/L	0.010	1.3	09/29/16 04:51	10/06/16	DJP	
6100429-03	Sample Location: #3 Bottle Filler									
	Lead	1030	ND	mg/L	0.002	0.02	09/29/16 04:52	10/06/16	DJP	
	Copper		0.055	mg/L	0.010	1.3	09/29/16 04:52	10/06/16	DJP	
6100429-04	Sample Location: #4 Drinking Fountain									
	Lead	1030	ND	mg/L	0.002	0.02	09/29/16 04:54	10/06/16	DJP	
	Copper		0.068	mg/L	0.010	1.3	09/29/16 04:54	10/06/16	DJP	
6100429-05	Sample Location: #5 Drinking Fountain									
	Lead	1030	ND	mg/L	0.002	0.02	09/29/16 04:54	10/06/16	DJP	
	Copper		0.065	mg/L	0.010	1.3	09/29/16 04:54	10/06/16	DJP	
6100429-06	Sample Location: #6 Drinking Fountain									
	Lead	1030	ND	mg/L	0.002	0.02	09/29/16 04:56	10/06/16	DJP	
	Copper		0.063	mg/L	0.010	1.3	09/29/16 04:56	10/06/16	DJP	
6100429-07	Sample Location: #7 Bottle Filler									
	Lead	1030	ND	mg/L	0.002	0.02	09/29/16 04:56	10/06/16	DJP	
	Copper		0.058	mg/L	0.010	1.3	09/29/16 04:56	10/06/16	DJP	
6100429-08	Sample Location: #8 Drinking Fountain									
	Lead	1030	ND	mg/L	0.002	0.02	09/29/16 05:02	10/06/16	DJP	
	Copper		0.114	mg/L	0.010	1.3	09/29/16 05:02	10/06/16	DJP	
6100429-09	Sample Location: #9 Drinking Fountain									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



# UMPQUA Research Company

626 NE Division St. - P.O. Box 609  
 Myrtle Creek, Oregon 97457  
 (541) 863-5201 Fax: (541) 863-6199  
 E-mail: Lab@URCmail.net  
 Internet: http://ChemLab.cc  
 ORELAP ID# OR100031

## ANALYSIS REPORT

URC # 6100429

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead		1030	ND	mg/L	0.002	0.02	09/29/16 05:03	10/06/16	DJP	
Copper			0.109	mg/L	0.010	1.3	09/29/16 05:03	10/06/16	DJP	
6100429-10	Sample Location: #11 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	09/29/16 05:07	10/06/16	DJP	
Copper			0.119	mg/L	0.010	1.3	09/29/16 05:07	10/06/16	DJP	
6100429-11	Sample Location: #12 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	09/29/16 05:10	10/06/16	DJP	
Copper			0.091	mg/L	0.010	1.3	09/29/16 05:10	10/06/16	DJP	
6100429-12	Sample Location: #13 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	09/29/16 05:11	10/06/16	DJP	
Copper			0.119	mg/L	0.010	1.3	09/29/16 05:11	10/06/16	DJP	
6100429-13	Sample Location: #14 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	09/29/16 05:15	10/06/16	DJP	
Copper			0.029	mg/L	0.010	1.3	09/29/16 05:15	10/06/16	DJP	
6100429-14	Sample Location: #15 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	09/29/16 05:16	10/06/16	DJP	
Copper			0.033	mg/L	0.010	1.3	09/29/16 05:16	10/06/16	DJP	
6100429-15	Sample Location: #16 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	09/29/16 05:19	10/06/16	DJP	
Copper			0.264	mg/L	0.010	1.3	09/29/16 05:19	10/06/16	DJP	
6100429-16	Sample Location: #17 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	09/29/16 05:20	10/06/16	DJP	
Copper			0.196	mg/L	0.010	1.3	09/29/16 05:20	10/06/16	DJP	
6100429-17	Sample Location: #22 Prep Sink									
Lead		1030	ND	mg/L	0.002	0.02	09/29/16 05:32	10/06/16	DJP	
Copper			0.059	mg/L	0.010	1.3	09/29/16 05:32	10/06/16	DJP	
6100429-18	Sample Location: #23 Bottle Filler									
Lead		1030	ND	mg/L	0.002	0.02	09/29/16 05:34	10/07/16	DJP	
Copper			0.070	mg/L	0.010	1.3	09/29/16 05:34	10/07/16	DJP	
6100429-19	Sample Location: #24 Drinking Fountain									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



# UMPQUA Research Company

626 NE Division St. - P.O. Box 609  
 Myrtle Creek, Oregon 97457  
 (541) 863-5201 Fax: (541) 863-6199  
 E-mail: Lab@URCmail.net  
 Internet: http://ChemLab.cc  
 ORELAP ID# OR100031

## ANALYSIS REPORT

URC # 6100429

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead		1030	ND	mg/L	0.002	0.02	09/29/16 05:35	10/07/16	DJP	
Copper			0.080	mg/L	0.010	1.3	09/29/16 05:35	10/07/16	DJP	
6100429-20	Sample Location: #18 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	09/30/16 05:52	10/07/16	DJP	
Copper			0.083	mg/L	0.010	1.3	09/30/16 05:52	10/07/16	DJP	
6100429-21	Sample Location: #19 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	09/30/16 05:54	10/07/16	DJP	
Copper			0.093	mg/L	0.010	1.3	09/30/16 05:54	10/07/16	DJP	
6100429-22	Sample Location: #20 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	09/30/16 05:54	10/07/16	DJP	
Copper			0.108	mg/L	0.010	1.3	09/30/16 05:54	10/07/16	DJP	
6100429-23	Sample Location: #21 Bottle Filler									
Lead		1030	ND	mg/L	0.002	0.02	09/30/16 05:55	10/07/16	DJP	
Copper			0.087	mg/L	0.010	1.3	09/30/16 05:55	10/07/16	DJP	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



## UMPQUA Research Company

626 NE Division St. - P.O. Box 609  
Myrtle Creek, Oregon 97457  
(541) 863-5201 Fax: (541) 863-6199  
E-mail: Lab@URCmail.net  
Internet: <http://ChemLab.cc>  
ORELAP ID# OR100031

## ANALYSIS REPORT

URC # 6100429

### Qualifiers and Definitions

DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the MRL (minimum reporting limit)
NA	Not Applicable
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
MRL	Minimum Reporting Limit
MDL	Minimum Detection Limit
MCL	Maximum Contamination Level
(‡)	ORELAP Accredited Analyte
(~)	Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

Tom Williams, Laboratory Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.