

# UMPQUA Research Company

626 NE Division St. - P.O. Box 609  
Myrtle Creek, Oregon 97457  
(541) 863-5201 Fax: (541) 863-6199  
E-mail: Lab@URCmail.net  
Internet: http://ChemLab.cc  
ORELAP ID# OR100031

## ANALYSIS REPORT

URC # 6102808

Bend LaPine Schools 1410 SE Wilson Ave. Bend, OR 97702	Project: 2016 Lead Testing Project #: LaPine Bus Garage  Client Contact: Mike Tiller	Date Reported: 11/02/16 Date Sampled: 10/27/16 04:15 Date Received: 10/28/16 08:50 Sampled By: Terry Glenn
--	---	---

Sample Location: #1 Lunch Room

URC Sample #: 6102808-01

Matrix: Drinking Water

### Metals


Analyte	Method	Code	Result	Units	MRL	MCL	Prepared	Analyzed	Analyst	Qualifier
Copper	EPA 200.8		0.032	mg/L	0.010	1.3	11/01/16	11/01/16	DJP	
Lead	EPA 200.8	1030	ND	mg/L	0.002	0.02	11/01/16	11/01/16	DJP	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



## UMPQUA Research Company

626 NE Division St. - P.O. Box 609  
Myrtle Creek, Oregon 97457  
(541) 863-5201 Fax: (541) 863-6199  
E-mail: Lab@URCmail.net  
Internet: <http://ChemLab.cc>  
ORELAP ID# OR100031

## ANALYSIS REPORT

URC # 6102808

### Qualifiers and Definitions

DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the MRL (minimum reporting limit)
NA	Not Applicable
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
MRL	Minimum Reporting Limit
MDL	Minimum Detection Limit
MCL	Maximum Contamination Level
(‡)	ORELAP Accredited Analyte
(~)	Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.  
This analytical report must be reproduced in its entirety.

---

Tom Williams, Laboratory Manager