

UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6102802

Bend LaPine Schools
 1410 SE Wilson Ave.
 Bend, OR 97702

Project: 2016 Lead Testing
 Project #: LaPine Middle School
 Client Contact: Mike Tiller

Date Reported: 10/28/16
 Date Received: 10/28/16 08:50
 Sampled By: Terry Glenn

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
6102802-01	Sample Location: #1 Drinking Fountain									
	Lead	1030	ND	mg/L	0.002	0.02	10/27/16 04:20	10/28/16	DJP	
	Copper		0.060	mg/L	0.010	1.3	10/27/16 04:20	10/28/16	DJP	
6102802-02	Sample Location: #2 Drinking Fountain									
	Lead	1030	ND	mg/L	0.002	0.02	10/27/16 04:21	10/28/16	DJP	
	Copper		0.025	mg/L	0.010	1.3	10/27/16 04:21	10/28/16	DJP	
6102802-03	Sample Location: #3 Drinking Fountain									
	Lead	1030	0.003	mg/L	0.002	0.02	10/27/16 04:25	10/28/16	DJP	
	Copper		0.023	mg/L	0.010	1.3	10/27/16 04:25	10/28/16	DJP	
6102802-04	Sample Location: #4-A Step 1 Drinking Fountain									
	Lead	1030	0.009	mg/L	0.002	0.02	10/27/16 04:33	10/28/16	DJP	
	Copper		0.043	mg/L	0.010	1.3	10/27/16 04:33	10/28/16	DJP	
6102802-05	Sample Location: #4-B Step 2 Drinking Fountain									
	Lead	1030	0.004	mg/L	0.002	0.02	10/27/16 04:34	10/28/16	DJP	
	Copper		0.027	mg/L	0.010	1.3	10/27/16 04:34	10/28/16	DJP	
6102802-06	Sample Location: #5 Drinking Fountain									
	Lead	1030	ND	mg/L	0.002	0.02	10/27/16 04:36	10/28/16	DJP	
	Copper		0.033	mg/L	0.010	1.3	10/27/16 04:36	10/28/16	DJP	
6102802-07	Sample Location: #6 Drinking Fountain									
	Lead	1030	ND	mg/L	0.002	0.02	10/27/16 04:39	10/28/16	DJP	
	Copper		0.594	mg/L	0.010	1.3	10/27/16 04:39	10/28/16	DJP	
6102802-08	Sample Location: #7 Bottle Filler									
	Lead	1030	ND	mg/L	0.002	0.02	10/27/16 04:40	10/28/16	DJP	
	Copper		0.704	mg/L	0.010	1.3	10/27/16 04:40	10/28/16	DJP	
6102802-09	Sample Location: #8 Prep Sink									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6102802

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead		1030	ND	mg/L	0.002	0.02	10/27/16 04:41	10/28/16	DJP	
Copper			0.040	mg/L	0.010	1.3	10/27/16 04:41	10/28/16	DJP	
6102802-10	Sample Location: #9 Prep Sink									
Lead		1030	0.002	mg/L	0.002	0.02	10/27/16 04:42	10/28/16	DJP	
Copper			0.026	mg/L	0.010	1.3	10/27/16 04:42	10/28/16	DJP	
6102802-11	Sample Location: #10 Prep Sink									
Lead		1030	ND	mg/L	0.002	0.02	10/27/16 04:43	10/28/16	DJP	
Copper			0.139	mg/L	0.010	1.3	10/27/16 04:43	10/28/16	DJP	
6102802-12	Sample Location: #11 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	10/27/16 04:45	10/28/16	DJP	
Copper			0.029	mg/L	0.010	1.3	10/27/16 04:45	10/28/16	DJP	
6102802-13	Sample Location: #12 Bottle Filler									
Lead		1030	ND	mg/L	0.002	0.02	10/27/16 04:46	10/28/16	DJP	
Copper			0.032	mg/L	0.010	1.3	10/27/16 04:46	10/28/16	DJP	
6102802-14	Sample Location: #13 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	10/27/16 04:48	10/28/16	DJP	
Copper			0.024	mg/L	0.010	1.3	10/27/16 04:48	10/28/16	DJP	
6102802-15	Sample Location: #14 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	10/27/16 04:49	10/28/16	DJP	
Copper			0.038	mg/L	0.010	1.3	10/27/16 04:49	10/28/16	DJP	
6102802-16	Sample Location: #15 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	10/27/16 04:50	10/28/16	DJP	
Copper			0.023	mg/L	0.010	1.3	10/27/16 04:50	10/28/16	DJP	
6102802-17	Sample Location: #16 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	10/27/16 04:51	10/28/16	DJP	
Copper			0.026	mg/L	0.010	1.3	10/27/16 04:51	10/28/16	DJP	
6102802-18	Sample Location: #17 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	10/27/16 04:52	10/28/16	DJP	
Copper			0.025	mg/L	0.010	1.3	10/27/16 04:52	10/28/16	DJP	
6102802-19	Sample Location: #18 Drinking Fountain									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6102802

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead		1030	ND	mg/L	0.002	0.02	10/27/16 04:53	10/28/16	DJP	
Copper			0.028	mg/L	0.010	1.3	10/27/16 04:53	10/28/16	DJP	
6102802-20	Sample Location: #19 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	10/27/16 04:58	10/28/16	DJP	
Copper			0.022	mg/L	0.010	1.3	10/27/16 04:58	10/28/16	DJP	
6102802-21	Sample Location: #20 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	10/27/16 05:00	10/28/16	DJP	
Copper			0.026	mg/L	0.010	1.3	10/27/16 05:00	10/28/16	DJP	
6102802-22	Sample Location: #21 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	10/27/16 05:02	10/28/16	DJP	
Copper			0.019	mg/L	0.010	1.3	10/27/16 05:02	10/28/16	DJP	
6102802-23	Sample Location: #22 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	10/27/16 05:05	10/28/16	DJP	
Copper			0.032	mg/L	0.010	1.3	10/27/16 05:05	10/28/16	DJP	
6102802-24	Sample Location: #23 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	10/27/16 05:08	10/28/16	DJP	
Copper			0.021	mg/L	0.010	1.3	10/27/16 05:08	10/28/16	DJP	
6102802-25	Sample Location: #24 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	10/27/16 05:09	10/28/16	DJP	
Copper			0.029	mg/L	0.010	1.3	10/27/16 05:09	10/28/16	DJP	
6102802-26	Sample Location: #25 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	10/27/16 05:10	10/28/16	DJP	
Copper			0.044	mg/L	0.010	1.3	10/27/16 05:10	10/28/16	DJP	
6102802-27	Sample Location: #26 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	10/27/16 05:15	10/28/16	DJP	
Copper			0.020	mg/L	0.010	1.3	10/27/16 05:15	10/28/16	DJP	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: <http://ChemLab.cc>
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6102802

Qualifiers and Definitions

DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the MRL (minimum reporting limit)
NA	Not Applicable
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
MRL	Minimum Reporting Limit
MDL	Minimum Detection Limit
MCL	Maximum Contamination Level
(‡)	ORELAP Accredited Analyte
(~)	Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager