

UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6060807

Bend LaPine Schools
 1410 SE Wilson Ave.
 Bend, OR 97702

Project: No Project
 Project #: No Project

Date Reported: 06/21/16
 Date Received: 06/08/16 10:00
 Sampled By: Various

Client Contact: Bend LaPine Schools

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
6060807-01	Sample Location: Bend High School									
Lead		1030	ND	mg/L	0.002	0.015	06/06/16 05:58	06/09/16	DJP	
Copper			0.132	mg/L	0.010	1.3	06/06/16 05:58	06/09/16	DJP	
6060807-02	Sample Location: Bear Creek Elementary									
Lead		1030	ND	mg/L	0.002	0.015	06/06/16 06:06	06/09/16	DJP	
Copper			0.161	mg/L	0.010	1.3	06/06/16 06:06	06/09/16	DJP	
6060807-03	Sample Location: Tamarack									
Lead		1030	ND	mg/L	0.002	0.015	06/06/16 06:13	06/09/16	DJP	
Copper			0.203	mg/L	0.010	1.3	06/06/16 06:13	06/09/16	DJP	
6060807-04	Sample Location: Transition Coop									
Lead		1030	ND	mg/L	0.002	0.015	06/06/16 06:16	06/09/16	DJP	
Copper			0.034	mg/L	0.010	1.3	06/06/16 06:16	06/09/16	DJP	
6060807-05	Sample Location: High Desert Middle School									
Lead		1030	ND	mg/L	0.002	0.015	06/06/16 06:16	06/09/16	DJP	
Copper			0.083	mg/L	0.010	1.3	06/06/16 06:16	06/09/16	DJP	
6060807-06	Sample Location: Silver Rail Elementary									
Lead		1030	ND	mg/L	0.002	0.015	06/06/16 06:33	06/09/16	DJP	
Copper			0.042	mg/L	0.010	1.3	06/06/16 06:33	06/09/16	DJP	
6060807-07	Sample Location: Jewel Elementary									
Lead		1030	ND	mg/L	0.002	0.015	06/06/16 06:40	06/09/16	DJP	
Copper			0.072	mg/L	0.010	1.3	06/06/16 06:40	06/09/16	DJP	
6060807-08	Sample Location: Marshall High School									
Lead		1030	ND	mg/L	0.002	0.015	06/06/16 05:55	06/09/16	DJP	
Copper			0.233	mg/L	0.010	1.3	06/06/16 05:55	06/09/16	DJP	
6060807-09	Sample Location: Pilot Butte Middle School									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6060807

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead		1030	ND	mg/L	0.002	0.015	06/06/16 06:03	06/09/16	DJP	
Copper			0.118	mg/L	0.010	1.3	06/06/16 06:03	06/09/16	DJP	
6060807-10	Sample Location: Ensworth Elementary									
Lead		1030	ND	mg/L	0.002	0.015	06/06/16 06:11	06/09/16	DJP	
Copper			0.186	mg/L	0.010	1.3	06/06/16 06:11	06/09/16	DJP	
6060807-11	Sample Location: Juniper Elementary									
Lead		1030	ND	mg/L	0.002	0.015	06/06/16 06:21	06/09/16	DJP	
Copper			0.227	mg/L	0.010	1.3	06/06/16 06:21	06/09/16	DJP	
6060807-12	Sample Location: Cascade Middle School									
Lead		1030	ND	mg/L	0.002	0.015	06/06/16 06:02	06/09/16	DJP	
Copper			0.080	mg/L	0.010	1.3	06/06/16 06:02	06/09/16	DJP	
6060807-13	Sample Location: Pineridge Elementary									
Lead		1030	ND	mg/L	0.002	0.015	06/06/16 06:23	06/09/16	DJP	
Copper			0.057	mg/L	0.010	1.3	06/06/16 06:23	06/09/16	DJP	
6060807-14	Sample Location: Elk Meadows Elementary									
Lead		1030	ND	mg/L	0.002	0.015	06/06/16 06:33	06/09/16	DJP	
Copper			0.057	mg/L	0.010	1.3	06/06/16 06:33	06/09/16	DJP	
6060807-15	Sample Location: Bend Transportation									
Lead		1030	0.002	mg/L	0.002	0.015	06/06/16 05:56	06/09/16	DJP	
Copper			0.033	mg/L	0.010	1.3	06/06/16 05:56	06/09/16	DJP	
6060807-16	Sample Location: Summit High School									
Lead		1030	ND	mg/L	0.002	0.015	06/06/16 06:10	06/09/16	DJP	
Copper			0.213	mg/L	0.010	1.3	06/06/16 06:10	06/09/16	DJP	
6060807-17	Sample Location: Pacific Crest Middle School									
Lead		1030	ND	mg/L	0.002	0.015	06/06/16 06:20	06/09/16	DJP	
Copper			0.137	mg/L	0.010	1.3	06/06/16 06:20	06/09/16	DJP	
6060807-18	Sample Location: Miller Elementary									
Lead		1030	ND	mg/L	0.002	0.015	06/06/16 06:25	06/09/16	DJP	
Copper			0.172	mg/L	0.010	1.3	06/06/16 06:25	06/09/16	DJP	
6060807-19	Sample Location: High Lakes Elementary									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6060807

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead		1030	ND	mg/L	0.002	0.015	06/06/16 06:30	06/09/16	DJP	
Copper			0.214	mg/L	0.010	1.3	06/06/16 06:30	06/09/16	DJP	
6060807-20	Sample Location: Education Center									
Lead		1030	0.004	mg/L	0.002	0.015	06/06/16 05:57	06/09/16	DJP	
Copper			0.017	mg/L	0.010	1.3	06/06/16 05:57	06/09/16	DJP	
6060807-21	Sample Location: Amity Creek Elementary									
Lead		1030	0.005	mg/L	0.002	0.015	06/06/16 06:03	06/09/16	DJP	
Copper			ND	mg/L	0.010	1.3	06/06/16 06:03	06/09/16	DJP	
6060807-22	Sample Location: Kingston Elementary									
Lead		1030	ND	mg/L	0.002	0.015	06/06/16 06:13	06/09/16	DJP	
Copper			0.249	mg/L	0.010	1.3	06/06/16 06:13	06/09/16	DJP	
6060807-23	Sample Location: Highland Elementary									
Lead		1030	0.002	mg/L	0.002	0.015	06/06/16 06:20	06/09/16	DJP	
Copper			0.283	mg/L	0.010	1.3	06/06/16 06:20	06/09/16	DJP	
6060807-24	Sample Location: Buckingham Elementary									
Lead		1030	ND	mg/L	0.002	0.015	06/06/16 05:55	06/09/16	DJP	
Copper			0.113	mg/L	0.010	1.3	06/06/16 05:55	06/09/16	DJP	
6060807-25	Sample Location: Mt. View High School									
Lead		1030	ND	mg/L	0.002	0.015	06/06/16 06:08	06/09/16	DJP	
Copper			0.182	mg/L	0.010	1.3	06/06/16 06:08	06/09/16	DJP	
6060807-26	Sample Location: Ponderosa Elementary									
Lead		1030	ND	mg/L	0.002	0.015	06/06/16 06:18	06/09/16	DJP	
Copper			0.068	mg/L	0.010	1.3	06/06/16 06:18	06/09/16	DJP	
6060807-27	Sample Location: Realms									
Lead		1030	ND	mg/L	0.002	0.015	06/06/16 06:15	06/09/16	DJP	
Copper			0.165	mg/L	0.010	1.3	06/06/16 06:15	06/09/16	DJP	
6060807-28	Sample Location: Skyview Middle School									
Lead		1030	ND	mg/L	0.002	0.015	06/06/16 06:30	06/09/16	DJP	
Copper			0.086	mg/L	0.010	1.3	06/06/16 06:30	06/09/16	DJP	
6060807-29	Sample Location: Lava Ridge Elementary									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6060807

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead		1030	ND	mg/L	0.002	0.015	06/06/16 06:45	06/09/16	DJP	
Copper			0.068	mg/L	0.010	1.3	06/06/16 06:45	06/09/16	DJP	
6060807-30	Sample Location: La Pine High School									
Lead		1030	ND	mg/L	0.002	0.015	06/07/16 05:10	06/09/16	DJP	
Copper			0.036	mg/L	0.010	1.3	06/07/16 05:10	06/09/16	DJP	
6060807-31	Sample Location: Maintenance Bldg. 3									
Lead		1030	0.002	mg/L	0.002	0.015	06/07/16 05:00	06/09/16	DJP	
Copper			0.196	mg/L	0.010	1.3	06/07/16 05:00	06/09/16	DJP	
6060807-32	Sample Location: Distribution Center									
Lead		1030	0.002	mg/L	0.002	0.015	06/07/16 05:10	06/09/16	DJP	
Copper			0.080	mg/L	0.010	1.3	06/07/16 05:10	06/09/16	DJP	
6060807-33	Sample Location: Three Rivers K-8									
Lead		1030	ND	mg/L	0.002	0.015	06/07/16 05:37	06/09/16	DJP	
Copper			0.132	mg/L	0.010	1.3	06/07/16 05:37	06/09/16	DJP	
6060807-34	Sample Location: LaPine Transportation									
Lead		1030	ND	mg/L	0.002	0.015	06/07/16 06:02	06/09/16	DJP	
Copper			0.026	mg/L	0.010	1.3	06/07/16 06:02	06/09/16	DJP	
6060807-35	Sample Location: LaPine Elementary									
Lead		1030	ND	mg/L	0.002	0.015	06/07/16 06:05	06/09/16	DJP	
Copper			0.023	mg/L	0.010	1.3	06/07/16 06:05	06/09/16	DJP	
6060807-36	Sample Location: LaPine Middle School									
Lead		1030	ND	mg/L	0.002	0.015	06/07/16 06:10	06/09/16	DJP	
Copper			0.028	mg/L	0.010	1.3	06/07/16 06:10	06/09/16	DJP	
6060807-37	Sample Location: Rosland Elementary									
Lead		1030	ND	mg/L	0.002	0.015	06/07/16 06:38	06/09/16	DJP	
Copper			0.036	mg/L	0.010	1.3	06/07/16 06:38	06/09/16	DJP	
6060807-38	Sample Location: LaPine Community Campus									
Lead		1030	ND	mg/L	0.002	0.015	06/07/16 06:25	06/09/16	DJP	
Copper			0.027	mg/L	0.010	1.3	06/07/16 06:25	06/09/16	DJP	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: <http://ChemLab.cc>
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6060807

Qualifiers and Definitions

DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the MRL (minimum reporting limit)
NA	Not Applicable
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
MRL	Minimum Reporting Limit
MDL	Minimum Detection Limit
MCL	Maximum Contamination Level
(‡)	ORELAP Accredited Analyte
(~)	Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager