

# UMPQUA Research Company

626 NE Division St. - P.O. Box 609  
 Myrtle Creek, Oregon 97457  
 (541) 863-5201 Fax: (541) 863-6199  
 E-mail: Lab@URCmail.net  
 Internet: http://ChemLab.cc  
 ORELAP ID# OR100031

## ANALYSIS REPORT

URC # 6101920

|  |  |   |
|--|--|---|
| Bend LaPine Schools<br>1410 SE Wilson Ave.<br>Bend, OR 97702 | Project: 2016 Lead Testing<br>Project #: Ponderosa Elementary<br>Client Contact: Mike Tiller | Date Reported: 10/28/16<br>Date Received: 10/19/16 08:55<br>Sampled By: Tom Everest |
|--|--|---|

Method: EPA 200.8

Matrix: Drinking Water


|            | Sample Location                       | Code | Result | Units | MRL   | MCL  | Sampled        | Analyzed | Analyst | Qualifier |
|------------|---------------------------------------|------|--------|-------|-------|------|----------------|----------|---------|-----------|
| 6101920-01 | Sample Location: #1 Drinking Fountain |      |        |       |       |      |                |          |         |           |
|            | Lead                                  | 1030 | ND     | mg/L  | 0.002 | 0.02 | 10/14/16 03:50 | 10/24/16 | DJP     |           |
|            | Copper                                |      | 0.090  | mg/L  | 0.010 | 1.3  | 10/14/16 03:50 | 10/24/16 | DJP     |           |
| 6101920-02 | Sample Location: #2 Drinking Fountain |      |        |       |       |      |                |          |         |           |
|            | Lead                                  | 1030 | ND     | mg/L  | 0.002 | 0.02 | 10/14/16 03:51 | 10/24/16 | DJP     |           |
|            | Copper                                |      | 0.049  | mg/L  | 0.010 | 1.3  | 10/14/16 03:51 | 10/24/16 | DJP     |           |
| 6101920-03 | Sample Location: #3 Bottle Filler     |      |        |       |       |      |                |          |         |           |
|            | Lead                                  | 1030 | ND     | mg/L  | 0.002 | 0.02 | 10/14/16 03:52 | 10/24/16 | DJP     |           |
|            | Copper                                |      | 0.056  | mg/L  | 0.010 | 1.3  | 10/14/16 03:52 | 10/24/16 | DJP     |           |
| 6101920-04 | Sample Location: #4 Drinking Fountain |      |        |       |       |      |                |          |         |           |
|            | Lead                                  | 1030 | ND     | mg/L  | 0.002 | 0.02 | 10/14/16 03:55 | 10/24/16 | DJP     |           |
|            | Copper                                |      | 0.079  | mg/L  | 0.010 | 1.3  | 10/14/16 03:55 | 10/24/16 | DJP     |           |
| 6101920-05 | Sample Location: #5 Drinking Fountain |      |        |       |       |      |                |          |         |           |
|            | Lead                                  | 1030 | ND     | mg/L  | 0.002 | 0.02 | 10/14/16 03:57 | 10/24/16 | DJP     |           |
|            | Copper                                |      | 0.065  | mg/L  | 0.010 | 1.3  | 10/14/16 03:57 | 10/24/16 | DJP     |           |
| 6101920-06 | Sample Location: #6 Drinking Fountain |      |        |       |       |      |                |          |         |           |
|            | Lead                                  | 1030 | ND     | mg/L  | 0.002 | 0.02 | 10/14/16 03:57 | 10/24/16 | DJP     |           |
|            | Copper                                |      | 0.065  | mg/L  | 0.010 | 1.3  | 10/14/16 03:57 | 10/24/16 | DJP     |           |
| 6101920-07 | Sample Location: #7 Drinking Fountain |      |        |       |       |      |                |          |         |           |
|            | Lead                                  | 1030 | ND     | mg/L  | 0.002 | 0.02 | 10/14/16 03:58 | 10/24/16 | DJP     |           |
|            | Copper                                |      | 0.091  | mg/L  | 0.010 | 1.3  | 10/14/16 03:58 | 10/24/16 | DJP     |           |
| 6101920-08 | Sample Location: #8 Prep Sink         |      |        |       |       |      |                |          |         |           |
|            | Lead                                  | 1030 | ND     | mg/L  | 0.002 | 0.02 | 10/14/16 04:00 | 10/24/16 | DJP     |           |
|            | Copper                                |      | 0.092  | mg/L  | 0.010 | 1.3  | 10/14/16 04:00 | 10/24/16 | DJP     |           |
| 6101920-09 | Sample Location: #9 Drinking Fountain |      |        |       |       |      |                |          |         |           |

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



**UMPQUA Research Company**

626 NE Division St. - P.O. Box 609  
Myrtle Creek, Oregon 97457  
(541) 863-5201 Fax: (541) 863-6199  
E-mail: Lab@URCmail.net  
Internet: http://ChemLab.cc  
ORELAP ID# OR100031

**ANALYSIS REPORT**

**URC # 6101920**

**Method: EPA 200.8**

Matrix: Drinking Water


|            | Sample Location                        | Code | Result | Units | MRL   | MCL  | Sampled        | Analyzed | Analyst | Qualifier |
|------------|--|------|--------|-------|-------|------|----------------|----------|---------|-----------|
|            |  | 1030 | ND     | mg/L  | 0.002 | 0.02 | 10/14/16 04:03 | 10/24/16 | DJP     |           |
|            |  |      | 0.080  | mg/L  | 0.010 | 1.3  | 10/14/16 04:03 | 10/24/16 | DJP     |           |
| 6101920-10 | Sample Location: #10 Drinking Fountain |      |        |       |       |      |                |          |         |           |
|            |  | 1030 | ND     | mg/L  | 0.002 | 0.02 | 10/14/16 04:05 | 10/24/16 | DJP     |           |
|            |  |      | 0.082  | mg/L  | 0.010 | 1.3  | 10/14/16 04:05 | 10/24/16 | DJP     |           |
| 6101920-11 | Sample Location: #11 Drinking Fountain |      |        |       |       |      |                |          |         |           |
|            |  | 1030 | ND     | mg/L  | 0.002 | 0.02 | 10/14/16 04:08 | 10/24/16 | DJP     |           |
|            |  |      | 0.077  | mg/L  | 0.010 | 1.3  | 10/14/16 04:08 | 10/24/16 | DJP     |           |
| 6101920-12 | Sample Location: #12 Drinking Fountain |      |        |       |       |      |                |          |         |           |
|            |  | 1030 | ND     | mg/L  | 0.002 | 0.02 | 10/14/16 04:08 | 10/24/16 | DJP     |           |
|            |  |      | 0.080  | mg/L  | 0.010 | 1.3  | 10/14/16 04:08 | 10/24/16 | DJP     |           |
| 6101920-13 | Sample Location: #13 Drinking Fountain |      |        |       |       |      |                |          |         |           |
|            |  | 1030 | ND     | mg/L  | 0.002 | 0.02 | 10/14/16 04:10 | 10/24/16 | DJP     |           |
|            |  |      | 0.077  | mg/L  | 0.010 | 1.3  | 10/14/16 04:10 | 10/24/16 | DJP     |           |

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



## UMPQUA Research Company

626 NE Division St. - P.O. Box 609  
Myrtle Creek, Oregon 97457  
(541) 863-5201 Fax: (541) 863-6199  
E-mail: Lab@URCmail.net  
Internet: <http://ChemLab.cc>  
ORELAP ID# OR100031

## ANALYSIS REPORT

URC # 6101920

### Qualifiers and Definitions

|     |  |
|-----|--|
| DET | Analyte DETECTED   |
| ND  | Analyte NOT DETECTED at or above the MRL (minimum reporting limit)   |
| NA  | Not Applicable   |
| NR  | Not Reported   |
| dry | Sample results reported on a dry weight basis  |
| RPD | Relative Percent Difference  |
| MRL | Minimum Reporting Limit  |
| MDL | Minimum Detection Limit  |
| MCL | Maximum Contamination Level  |
| (‡) | ORELAP Accredited Analyte  |
| (~) | Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values. |

UMPQUA Research Company/MC

Tom Williams, Laboratory Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.