

UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6100422

Bend LaPine Schools 1410 SE Wilson Ave. Bend, OR 97702	Project: No Project Project #: LaPine High School 51633 Coach Rd, LaPine Or Client Contact: Bend LaPine Schools	Date Reported: 10/12/16 Date Received: 10/04/16 12:00 Sampled By: Terry Glenn
--	--	---

Method: EPA 200.8

Matrix: Drinking Water

	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
6100422-01	Sample Location: #1 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	09/30/16 04:20	10/05/16	DJP	
Copper			0.026	mg/L	0.010	1.3	09/30/16 04:20	10/05/16	DJP	
6100422-02	Sample Location: #2 Prep Sink									
Lead		1030	ND	mg/L	0.002	0.02	09/30/16 04:23	10/05/16	DJP	
Copper			0.018	mg/L	0.010	1.3	09/30/16 04:23	10/05/16	DJP	
6100422-03	Sample Location: #3 Kettle Cooker									
Lead		1030	0.002	mg/L	0.002	0.02	09/30/16 04:25	10/05/16	DJP	
Copper			0.031	mg/L	0.010	1.3	09/30/16 04:25	10/05/16	DJP	
6100422-04	Sample Location: #4 Prep Sink									
Lead		1030	ND	mg/L	0.002	0.02	09/30/16 04:26	10/05/16	DJP	
Copper			0.027	mg/L	0.010	1.3	09/30/16 04:26	10/05/16	DJP	
6100422-05	Sample Location: #5 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	09/30/16 04:30	10/05/16	DJP	
Copper			0.029	mg/L	0.010	1.3	09/30/16 04:30	10/05/16	DJP	
6100422-06	Sample Location: #6 Bottle Filler									
Lead		1030	ND	mg/L	0.002	0.02	09/30/16 04:31	10/05/16	DJP	
Copper			0.028	mg/L	0.010	1.3	09/30/16 04:31	10/05/16	DJP	
6100422-07	Sample Location: #7 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	09/30/16 04:34	10/05/16	DJP	
Copper			0.022	mg/L	0.010	1.3	09/30/16 04:34	10/05/16	DJP	
6100422-08	Sample Location: #8 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	09/30/16 04:36	10/05/16	DJP	
Copper			0.031	mg/L	0.010	1.3	09/30/16 04:36	10/05/16	DJP	
6100422-09	Sample Location: #9 Drinking Fountain									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6100422

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead		1030	ND	mg/L	0.002	0.02	09/30/16 04:39	10/05/16	DJP	
Copper			0.036	mg/L	0.010	1.3	09/30/16 04:39	10/05/16	DJP	
6100422-10	Sample Location: #10 Bottle Filler									
Lead		1030	ND	mg/L	0.002	0.02	09/30/16 04:42	10/05/16	DJP	
Copper			0.023	mg/L	0.010	1.3	09/30/16 04:42	10/05/16	DJP	
6100422-11	Sample Location: #11 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	09/30/16 04:43	10/05/16	DJP	
Copper			0.021	mg/L	0.010	1.3	09/30/16 04:43	10/05/16	DJP	
6100422-12	Sample Location: #12 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	09/30/16 04:45	10/05/16	DJP	
Copper			0.086	mg/L	0.010	1.3	09/30/16 04:45	10/05/16	DJP	
6100422-13	Sample Location: #13 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	09/30/16 04:46	10/05/16	DJP	
Copper			0.032	mg/L	0.010	1.3	09/30/16 04:46	10/05/16	DJP	
6100422-14	Sample Location: #14 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	09/30/16 04:47	10/05/16	DJP	
Copper			0.027	mg/L	0.010	1.3	09/30/16 04:47	10/05/16	DJP	
6100422-15	Sample Location: #15 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	09/30/16 04:45	10/05/16	DJP	
Copper			0.017	mg/L	0.010	1.3	09/30/16 04:45	10/05/16	DJP	
6100422-16	Sample Location: #16 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	09/30/16 04:44	10/05/16	DJP	
Copper			0.017	mg/L	0.010	1.3	09/30/16 04:44	10/05/16	DJP	
6100422-17	Sample Location: #17 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	09/30/16 04:54	10/05/16	DJP	
Copper			0.020	mg/L	0.010	1.3	09/30/16 04:54	10/05/16	DJP	
6100422-18	Sample Location: #18 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	09/30/16 04:55	10/05/16	DJP	
Copper			0.016	mg/L	0.010	1.3	09/30/16 04:55	10/05/16	DJP	
6100422-19	Sample Location: #19 Drinking Fountain									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: http://ChemLab.cc
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6100422

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead		1030	ND	mg/L	0.002	0.02	09/30/16 05:04	10/05/16	DJP	
Copper			0.017	mg/L	0.010	1.3	09/30/16 05:04	10/05/16	DJP	
6100422-20	Sample Location: #20 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	09/30/16 05:03	10/05/16	DJP	
Copper			0.025	mg/L	0.010	1.3	09/30/16 05:03	10/05/16	DJP	
6100422-21	Sample Location: #21 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	09/30/16 05:07	10/05/16	DJP	
Copper			0.023	mg/L	0.010	1.3	09/30/16 05:07	10/05/16	DJP	
6100422-22	Sample Location: #22 Drinking Fountain									
Lead		1030	0.002	mg/L	0.002	0.02	09/30/16 05:14	10/05/16	DJP	
Copper			0.022	mg/L	0.010	1.3	09/30/16 05:14	10/05/16	DJP	
6100422-23	Sample Location: #23 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	09/30/16 05:16	10/05/16	DJP	
Copper			0.033	mg/L	0.010	1.3	09/30/16 05:16	10/05/16	DJP	
6100422-24	Sample Location: #24 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	09/30/16 05:17	10/05/16	DJP	
Copper			0.035	mg/L	0.010	1.3	09/30/16 05:17	10/05/16	DJP	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: <http://ChemLab.cc>
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6100422

Qualifiers and Definitions

DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the MRL (minimum reporting limit)
NA	Not Applicable
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
MRL	Minimum Reporting Limit
MDL	Minimum Detection Limit
MCL	Maximum Contamination Level
(‡)	ORELAP Accredited Analyte
(~)	Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

Tom Williams, Laboratory Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.