

UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6112902

Bend LaPine Schools
 1410 SE Wilson Ave.
 Bend, OR 97702

Project: 2016 Lead Testing
 Project #: Amity Creek Elementary
 Client Contact: Mike Tiller

Date Reported: 12/01/16
 Date Received: 11/29/16 09:00
 Sampled By: Tom Everest

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
6112902-01	Sample Location: #1 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	11/23/16 05:45	11/30/16	DJP	
Copper			0.088	mg/L	0.010	1.3	11/23/16 05:45	11/30/16	DJP	
6112902-02	Sample Location: #2 Drinking Fountain									
Lead		1030	0.002	mg/L	0.002	0.02	11/23/16 05:45	11/30/16	DJP	
Copper			0.107	mg/L	0.010	1.3	11/23/16 05:45	11/30/16	DJP	
6112902-03	Sample Location: #3 Bottle Filler									
Lead		1030	0.002	mg/L	0.002	0.02	11/23/16 05:46	11/30/16	DJP	
Copper			0.105	mg/L	0.010	1.3	11/23/16 05:46	11/30/16	DJP	
6112902-04	Sample Location: #4 Faucet									
Lead		1030	0.004	mg/L	0.002	0.02	11/23/16 05:46	11/30/16	DJP	
Copper			0.095	mg/L	0.010	1.3	11/23/16 05:46	11/30/16	DJP	
6112902-05	Sample Location: #5 Faucet									
Lead		1030	0.008	mg/L	0.002	0.02	11/23/16 05:49	11/30/16	DJP	
Copper			ND	mg/L	0.010	1.3	11/23/16 05:49	11/30/16	DJP	
6112902-06	Sample Location: #6 Faucet									
Lead		1030	0.003	mg/L	0.002	0.02	11/23/16 05:49	11/30/16	DJP	
Copper			0.046	mg/L	0.010	1.3	11/23/16 05:49	11/30/16	DJP	
6112902-07	Sample Location: #7 Faucet									
Lead		1030	0.008	mg/L	0.002	0.02	11/23/16 05:50	11/30/16	DJP	
Copper			0.118	mg/L	0.010	1.3	11/23/16 05:50	11/30/16	DJP	
6112902-08	Sample Location: #8 Faucet									
Lead		1030	0.009	mg/L	0.002	0.02	11/23/16 05:53	11/30/16	DJP	
Copper			0.097	mg/L	0.010	1.3	11/23/16 05:53	11/30/16	DJP	
6112902-09	Sample Location: #9 Drinking Fountain									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6112902

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead		1030	0.004	mg/L	0.002	0.02	11/23/16 05:54	11/30/16	DJP	
Copper			ND	mg/L	0.010	1.3	11/23/16 05:54	11/30/16	DJP	
6112902-10	Sample Location: #10 Faucet									
Lead		1030	0.004	mg/L	0.002	0.02	11/23/16 05:55	11/30/16	DJP	
Copper			0.082	mg/L	0.010	1.3	11/23/16 05:55	11/30/16	DJP	
6112902-11	Sample Location: #11 Drinking Fountain									
Lead		1030	0.004	mg/L	0.002	0.02	11/23/16 05:55	11/30/16	DJP	
Copper			ND	mg/L	0.010	1.3	11/23/16 05:55	11/30/16	DJP	
6112902-12	Sample Location: #12 Faucet									
Lead		1030	0.007	mg/L	0.002	0.02	11/23/16 05:58	11/30/16	DJP	
Copper			0.079	mg/L	0.010	1.3	11/23/16 05:58	11/30/16	DJP	
6112902-13	Sample Location: #13 Drinking Fountain									
Lead		1030	0.004	mg/L	0.002	0.02	11/23/16 05:58	11/30/16	DJP	
Copper			0.013	mg/L	0.010	1.3	11/23/16 05:58	11/30/16	DJP	
6112902-14	Sample Location: #14 Faucet									
Lead		1030	0.006	mg/L	0.002	0.02	11/23/16 06:00	11/30/16	DJP	
Copper			0.078	mg/L	0.010	1.3	11/23/16 06:00	11/30/16	DJP	
6112902-15	Sample Location: #15 Drinking Fountain									
Lead		1030	0.004	mg/L	0.002	0.02	11/23/16 06:00	11/30/16	DJP	
Copper			ND	mg/L	0.010	1.3	11/23/16 06:00	11/30/16	DJP	
6112902-16	Sample Location: #16 Faucet									
Lead		1030	0.004	mg/L	0.002	0.02	11/23/16 06:02	11/30/16	DJP	
Copper			0.097	mg/L	0.010	1.3	11/23/16 06:02	11/30/16	DJP	
6112902-17	Sample Location: #17 Drinking Fountain									
Lead		1030	0.003	mg/L	0.002	0.02	11/23/16 06:02	11/30/16	DJP	
Copper			0.010	mg/L	0.010	1.3	11/23/16 06:02	11/30/16	DJP	
6112902-18	Sample Location: #18 Faucet									
Lead		1030	0.003	mg/L	0.002	0.02	11/23/16 06:04	11/30/16	DJP	
Copper			0.099	mg/L	0.010	1.3	11/23/16 06:04	11/30/16	DJP	
6112902-19	Sample Location: #19 Drinking Fountain									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6112902

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead		1030	0.004	mg/L	0.002	0.02	11/23/16 06:04	11/30/16	DJP	
Copper			ND	mg/L	0.010	1.3	11/23/16 06:04	11/30/16	DJP	
6112902-20	Sample Location: #20 Prep Sink									
Lead		1030	ND	mg/L	0.002	0.02	11/23/16 06:07	11/30/16	DJP	
Copper			0.283	mg/L	0.010	1.3	11/23/16 06:07	11/30/16	DJP	
6112902-21	Sample Location: #21 Faucet									
Lead		1030	0.003	mg/L	0.002	0.02	11/23/16 06:10	11/30/16	DJP	
Copper			0.742	mg/L	0.010	1.3	11/23/16 06:10	11/30/16	DJP	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: <http://ChemLab.cc>
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6112902

Qualifiers and Definitions

DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the MRL (minimum reporting limit)
NA	Not Applicable
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
MRL	Minimum Reporting Limit
MDL	Minimum Detection Limit
MCL	Maximum Contamination Level
(‡)	ORELAP Accredited Analyte
(~)	Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager