



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6101917

Bend LaPine Schools 1410 SE Wilson Ave. Bend, OR 97702	Project: 2016 Lead Testing Project #: Lava Ridge Elementary Client Contact: Mike Tiller	Date Reported: 10/28/16 Date Received: 10/19/16 08:55 Sampled By: KC Thrasher
--	---	---

Method: EPA 200.8

Matrix: Drinking Water

	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
6101917-01	Sample Location: #1 Bottle Filler									
	Lead	1030	ND	mg/L	0.002	0.02	10/14/16 04:04	10/20/16	DJP	
	Copper		0.034	mg/L	0.010	1.3	10/14/16 04:04	10/20/16	DJP	
6101917-02	Sample Location: #2 Drinking Fountain									
	Lead	1030	ND	mg/L	0.002	0.02	10/14/16 04:04	10/20/16	DJP	
	Copper		0.040	mg/L	0.010	1.3	10/14/16 04:04	10/20/16	DJP	
6101917-03	Sample Location: #3 Prep Sink									
	Lead	1030	ND	mg/L	0.002	0.02	10/14/16 04:06	10/20/16	DJP	
	Copper		0.041	mg/L	0.010	1.3	10/14/16 04:06	10/20/16	DJP	
6101917-04	Sample Location: #4 Drinking Fountain									
	Lead	1030	0.002	mg/L	0.002	0.02	10/14/16 04:09	10/20/16	DJP	
	Copper		0.081	mg/L	0.010	1.3	10/14/16 04:09	10/20/16	DJP	
6101917-05	Sample Location: #5 Drinking Fountain									
	Lead	1030	ND	mg/L	0.002	0.02	10/14/16 04:10	10/20/16	DJP	
	Copper		0.067	mg/L	0.010	1.3	10/14/16 04:10	10/20/16	DJP	
6101917-06	Sample Location: #6 Drinking Fountain									
	Lead	1030	ND	mg/L	0.002	0.02	10/14/16 04:11	10/20/16	DJP	
	Copper		0.068	mg/L	0.010	1.3	10/14/16 04:11	10/20/16	DJP	
6101917-07	Sample Location: #7 Drinking Fountain									
	Lead	1030	ND	mg/L	0.002	0.02	10/14/16 04:13	10/20/16	DJP	
	Copper		0.067	mg/L	0.010	1.3	10/14/16 04:13	10/20/16	DJP	
6101917-08	Sample Location: #8 Drinking Fountain									
	Lead	1030	ND	mg/L	0.002	0.02	10/14/16 04:15	10/20/16	DJP	
	Copper		0.074	mg/L	0.010	1.3	10/14/16 04:15	10/20/16	DJP	
6101917-09	Sample Location: #9 Drinking Fountain									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6101917

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
		1030	ND	mg/L	0.002	0.02	10/14/16 04:16	10/20/16	DJP	
			0.069	mg/L	0.010	1.3	10/14/16 04:16	10/20/16	DJP	
6101917-10	Sample Location: #10 Drinking Fountain									
		1030	ND	mg/L	0.002	0.02	10/14/16 04:17	10/20/16	DJP	
			0.070	mg/L	0.010	1.3	10/14/16 04:17	10/20/16	DJP	
6101917-11	Sample Location: #11 Drinking Fountain									
		1030	ND	mg/L	0.002	0.02	10/14/16 04:22	10/20/16	DJP	
			0.062	mg/L	0.010	1.3	10/14/16 04:22	10/20/16	DJP	
6101917-12	Sample Location: #12 Drinking Fountain									
		1030	ND	mg/L	0.002	0.02	10/14/16 04:24	10/20/16	DJP	
			0.066	mg/L	0.010	1.3	10/14/16 04:24	10/20/16	DJP	
6101917-13	Sample Location: #13 Drinking Fountain									
		1030	ND	mg/L	0.002	0.02	10/14/16 04:25	10/20/16	DJP	
			0.066	mg/L	0.010	1.3	10/14/16 04:25	10/20/16	DJP	
6101917-14	Sample Location: #14 Drinking Fountain									
		1030	ND	mg/L	0.002	0.02	10/14/16 04:26	10/20/16	DJP	
			0.075	mg/L	0.010	1.3	10/14/16 04:26	10/20/16	DJP	
6101917-15	Sample Location: #15 Drinking Fountain									
		1030	ND	mg/L	0.002	0.02	10/14/16 04:27	10/20/16	DJP	
			0.074	mg/L	0.010	1.3	10/14/16 04:27	10/20/16	DJP	
6101917-16	Sample Location: #16 Drinking Fountain									
		1030	ND	mg/L	0.002	0.02	10/14/16 04:29	10/20/16	DJP	
			0.069	mg/L	0.010	1.3	10/14/16 04:29	10/20/16	DJP	
6101917-17	Sample Location: #17 Drinking Fountain									
		1030	ND	mg/L	0.002	0.02	10/14/16 04:30	10/20/16	DJP	
			0.070	mg/L	0.010	1.3	10/14/16 04:30	10/20/16	DJP	
6101917-18	Sample Location: #18 Drinking Fountain									
		1030	ND	mg/L	0.002	0.02	10/14/16 04:34	10/20/16	DJP	
			0.078	mg/L	0.010	1.3	10/14/16 04:34	10/20/16	DJP	
6101917-19	Sample Location: #19 Drinking Fountain									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6101917

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
		1030	0.003	mg/L	0.002	0.02	10/14/16 04:35	10/20/16	DJP	
			0.069	mg/L	0.010	1.3	10/14/16 04:35	10/20/16	DJP	
6101917-20	Sample Location: #20 Drinking Fountain									
		1030	0.002	mg/L	0.002	0.02	10/14/16 04:38	10/20/16	DJP	
			0.076	mg/L	0.010	1.3	10/14/16 04:38	10/20/16	DJP	
6101917-21	Sample Location: #21 Drinking Fountain									
		1030	ND	mg/L	0.002	0.02	10/14/16 04:40	10/20/16	DJP	
			0.073	mg/L	0.010	1.3	10/14/16 04:40	10/20/16	DJP	
6101917-22	Sample Location: #22 Drinking Fountain									
		1030	ND	mg/L	0.002	0.02	10/14/16 04:41	10/20/16	DJP	
			0.072	mg/L	0.010	1.3	10/14/16 04:41	10/20/16	DJP	
6101917-23	Sample Location: #23 Drinking Fountain									
		1030	ND	mg/L	0.002	0.02	10/14/16 04:42	10/20/16	DJP	
			0.071	mg/L	0.010	1.3	10/14/16 04:42	10/20/16	DJP	
6101917-24	Sample Location: #24 Drinking Fountain									
		1030	ND	mg/L	0.002	0.02	10/14/16 04:44	10/20/16	DJP	
			0.072	mg/L	0.010	1.3	10/14/16 04:44	10/20/16	DJP	
6101917-25	Sample Location: #25 Drinking Fountain									
		1030	ND	mg/L	0.002	0.02	10/14/16 04:44	10/20/16	DJP	
			0.068	mg/L	0.010	1.3	10/14/16 04:44	10/20/16	DJP	
6101917-26	Sample Location: #26 Drinking Fountain									
		1030	ND	mg/L	0.002	0.02	10/14/16 04:45	10/20/16	DJP	
			0.069	mg/L	0.010	1.3	10/14/16 04:45	10/20/16	DJP	
6101917-27	Sample Location: #27 Drinking Fountain									
		1030	ND	mg/L	0.002	0.02	10/14/16 04:47	10/20/16	DJP	
			0.077	mg/L	0.010	1.3	10/14/16 04:47	10/20/16	DJP	
6101917-28	Sample Location: #28 Drinking Fountain									
		1030	ND	mg/L	0.002	0.02	10/14/16 04:50	10/20/16	DJP	
			0.063	mg/L	0.010	1.3	10/14/16 04:50	10/20/16	DJP	
6101917-29	Sample Location: #29 Drinking Fountain									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6101917

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
		1030	ND	mg/L	0.002	0.02	10/14/16 04:51	10/20/16	DJP	
			0.069	mg/L	0.010	1.3	10/14/16 04:51	10/20/16	DJP	
6101917-30	Sample Location: #30 Drinking Fountain									
		1030	ND	mg/L	0.002	0.02	10/14/16 04:52	10/20/16	DJP	
			0.093	mg/L	0.010	1.3	10/14/16 04:52	10/20/16	DJP	
6101917-31	Sample Location: #31 Drinking Fountain									
		1030	ND	mg/L	0.002	0.02	10/14/16 04:53	10/20/16	DJP	
			0.071	mg/L	0.010	1.3	10/14/16 04:53	10/20/16	DJP	
6101917-32	Sample Location: #32 Drinking Fountain									
		1030	ND	mg/L	0.002	0.02	10/14/16 04:55	10/20/16	DJP	
			0.065	mg/L	0.010	1.3	10/14/16 04:55	10/20/16	DJP	
6101917-33	Sample Location: #33 Drinking Fountain									
		1030	ND	mg/L	0.002	0.02	10/14/16 04:56	10/20/16	DJP	
			0.069	mg/L	0.010	1.3	10/14/16 04:56	10/20/16	DJP	
6101917-34	Sample Location: #34 Drinking Fountain									
		1030	ND	mg/L	0.002	0.02	10/14/16 04:57	10/20/16	DJP	
			0.067	mg/L	0.010	1.3	10/14/16 04:57	10/20/16	DJP	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: <http://ChemLab.cc>
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6101917

Qualifiers and Definitions

DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the MRL (minimum reporting limit)
NA	Not Applicable
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
MRL	Minimum Reporting Limit
MDL	Minimum Detection Limit
MCL	Maximum Contamination Level
(‡)	ORELAP Accredited Analyte
(~)	Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

Tom Williams, Laboratory Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document.
This analytical report must be reproduced in its entirety.