

Healthy and Safe Schools Plan
Reduce Lead Exposure in Drinking Water
Phase II

Per the recommendation of the Oregon Health Authority and the Oregon Department of Education, the Bend-La Pine Schools implemented a plan for testing lead levels in the drinking water throughout the District. Phase I tests were completed by October 1, 2016. Phase II tests were delivered to Umpqua Research by November 1, 2016.

1. Test all remaining buildings:
 - a. Elk Meadow, 1994
 - b. Ensworth, 2003
 - c. High Lakes, 1998
 - d. La Pine Elementary, 1994
 - e. Lava Ridge, 1993
 - f. Pine Ridge, 2009
 - g. Ponderosa, 2007
 - h. Rosland, 2010
 - i. Silver Rail, 2015
 - j. Three Rivers, 1992
 - k. WE Miller, 2009
 - l. Westside Village at Kingston, 2009
 - m. High Desert, 1992
 - n. Pacific Crest, 2015
 - o. REALMS, 1991
 - p. Sky View, 1999
 - q. Marshall, 2005
 - r. Summit, 2002
 - s. Tamarack, 1999
 - t. Transition Co-Op, 2012
 - u. Bend Transportation, 1948
 - v. La Pine Transportation, 1980
 - w. Maintenance, 2003
 - x. Warehouse (Distribution)

2. Test all of the following at the outlet on the customer side of the water meter:
 - a. Drinking Fountains
 - b. Bubblers
 - c. Food Prep Areas

3. Step 1:
 - a. The first sample was collected from a tap located as near as possible to the service connection and samples were collected before the facility opened. The water sat in the pipes unused for at

least 8 hours but not more than 18 hours before the sample was taken.

- b. All tests samples were sent to Umpqua Research and none tested positive for lead over 20ppb.
 - c. Future testing will be dependent on Public Works testing, which is done every three years. If there are changes within any of the municipal water systems that service the District, testing will be done on the sites that are specific to that water system to ensure the water coming into the sites is within the allowable lead limit. Public Works providers include, City of Bend, Avion Water, Sunriver Water and City of La Pine. Areas of testing will include:
 - i. Drinking Fountains
 - ii. Bubblers
 - iii. Food Prep Areas
4. All test results from Phase II are posted on the Bend-La Pine Schools website and can be found at:
<https://www.bend.k12.or.us/district/organization/healthy-safe-facilities>.

Results can also be requested via email or a hard copy can be attained at the Administration Building.