

UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6101912

Bend LaPine Schools 1410 SE Wilson Ave. Bend, OR 97702	Project: 2016 Lead Testing Project #: Ensworth Elementary Client Contact: Mike Tiller	Date Reported: 10/28/16 Date Received: 10/19/16 08:55 Sampled By: Tom Everest
--	---	---

Method: EPA 200.8

Matrix: Drinking Water

	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
6101912-01	Sample Location: #1 Prep Sink									
	Lead	1030	ND	mg/L	0.002	0.02	10/14/16 04:26	10/20/16	DJP	
	Copper		0.028	mg/L	0.010	1.3	10/14/16 04:26	10/20/16	DJP	
6101912-02	Sample Location: #2 Drinking Fountain									
	Lead	1030	ND	mg/L	0.002	0.02	10/14/16 04:27	10/20/16	DJP	
	Copper		0.075	mg/L	0.010	1.3	10/14/16 04:27	10/20/16	DJP	
6101912-03	Sample Location: #3 Drinking Fountain									
	Lead	1030	ND	mg/L	0.002	0.02	10/14/16 04:27	10/20/16	DJP	
	Copper		0.062	mg/L	0.010	1.3	10/14/16 04:27	10/20/16	DJP	
6101912-04	Sample Location: #4 Drinking Fountain									
	Lead	1030	ND	mg/L	0.002	0.02	10/14/16 04:29	10/20/16	DJP	
	Copper		0.094	mg/L	0.010	1.3	10/14/16 04:29	10/20/16	DJP	
6101912-05	Sample Location: #5 Bottle Filler									
	Lead	1030	ND	mg/L	0.002	0.02	10/14/16 04:29	10/20/16	DJP	
	Copper		0.099	mg/L	0.010	1.3	10/14/16 04:29	10/20/16	DJP	
6101912-06	Sample Location: #6 Drinking Fountain									
	Lead	1030	ND	mg/L	0.002	0.02	10/14/16 04:33	10/20/16	DJP	
	Copper		0.126	mg/L	0.010	1.3	10/14/16 04:33	10/20/16	DJP	
6101912-07	Sample Location: #7 Drinking Fountain									
	Lead	1030	ND	mg/L	0.002	0.02	10/14/16 04:35	10/20/16	DJP	
	Copper		0.101	mg/L	0.010	1.3	10/14/16 04:35	10/20/16	DJP	
6101912-08	Sample Location: #8 Drinking Fountain									
	Lead	1030	ND	mg/L	0.002	0.02	10/14/16 04:36	10/20/16	DJP	
	Copper		0.097	mg/L	0.010	1.3	10/14/16 04:36	10/20/16	DJP	
6101912-09	Sample Location: #9 Drinking Fountain									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6101912

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead		1030	ND	mg/L	0.002	0.02	10/14/16 04:39	10/20/16	DJP	
Copper			0.114	mg/L	0.010	1.3	10/14/16 04:39	10/20/16	DJP	
6101912-10	Sample Location: #10 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	10/14/16 04:42	10/20/16	DJP	
Copper			0.114	mg/L	0.010	1.3	10/14/16 04:42	10/20/16	DJP	
6101912-11	Sample Location: #11 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	10/14/16 04:43	10/20/16	DJP	
Copper			0.127	mg/L	0.010	1.3	10/14/16 04:43	10/20/16	DJP	
6101912-12	Sample Location: #12 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	10/14/16 04:46	10/20/16	DJP	
Copper			0.140	mg/L	0.010	1.3	10/14/16 04:46	10/20/16	DJP	
6101912-13	Sample Location: #13 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	10/14/16 04:48	10/20/16	DJP	
Copper			0.112	mg/L	0.010	1.3	10/14/16 04:48	10/20/16	DJP	
6101912-14	Sample Location: #14 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	10/14/16 04:49	10/20/16	DJP	
Copper			0.110	mg/L	0.010	1.3	10/14/16 04:49	10/20/16	DJP	
6101912-15	Sample Location: #15 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	10/14/16 04:53	10/20/16	DJP	
Copper			0.127	mg/L	0.010	1.3	10/14/16 04:53	10/20/16	DJP	
6101912-16	Sample Location: #16 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	10/14/16 04:54	10/20/16	DJP	
Copper			0.121	mg/L	0.010	1.3	10/14/16 04:54	10/20/16	DJP	
6101912-17	Sample Location: #17 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	10/14/16 04:55	10/20/16	DJP	
Copper			0.129	mg/L	0.010	1.3	10/14/16 04:55	10/20/16	DJP	
6101912-18	Sample Location: #18 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	10/14/16 04:58	10/20/16	DJP	
Copper			0.125	mg/L	0.010	1.3	10/14/16 04:58	10/20/16	DJP	
6101912-19	Sample Location: #19 Drinking Fountain									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: http://ChemLab.cc
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6101912

Method: EPA 200.8


Matrix: Drinking Water

	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead		1030	ND	mg/L	0.002	0.02	10/14/16 05:00	10/20/16	DJP	
Copper			0.128	mg/L	0.010	1.3	10/14/16 05:00	10/20/16	DJP	
6101912-20	Sample Location: #20 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	10/14/16 05:01	10/20/16	DJP	
Copper			0.116	mg/L	0.010	1.3	10/14/16 05:01	10/20/16	DJP	

UMPQUA Research Company/MC

Tom Williams, Laboratory Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document.
This analytical report must be reproduced in its entirety.



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: <http://ChemLab.cc>
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6101912

Qualifiers and Definitions

DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the MRL (minimum reporting limit)
NA	Not Applicable
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
MRL	Minimum Reporting Limit
MDL	Minimum Detection Limit
MCL	Maximum Contamination Level
(‡)	ORELAP Accredited Analyte
(~)	Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

Tom Williams, Laboratory Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.