

UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6102412

Bend LaPine Schools 1410 SE Wilson Ave. Bend, OR 97702	Project: 2016 Lead Testing Project #: Summit High School Client Contact: Mike Tiller	Date Reported: 10/28/16 Date Received: 10/24/16 12:00 Sampled By: Tom Everest
--	--	---

Method: EPA 200.8


Matrix: Drinking Water

	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
6102412-01	Sample Location: #1 Prep Sink									
Lead		1030	ND	mg/L	0.002	0.02	10/21/16 04:40	10/27/16	DJP	
Copper			0.075	mg/L	0.010	1.3	10/21/16 04:40	10/27/16	DJP	
6102412-02	Sample Location: #2 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	10/21/16 04:43	10/27/16	DJP	
Copper			0.110	mg/L	0.010	1.3	10/21/16 04:43	10/27/16	DJP	
6102412-03	Sample Location: #3 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	10/21/16 04:43	10/27/16	DJP	
Copper			0.096	mg/L	0.010	1.3	10/21/16 04:43	10/27/16	DJP	
6102412-04	Sample Location: #4 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	10/21/16 04:45	10/27/16	DJP	
Copper			0.108	mg/L	0.010	1.3	10/21/16 04:45	10/27/16	DJP	
6102412-05	Sample Location: #5 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	10/21/16 04:45	10/27/16	DJP	
Copper			0.100	mg/L	0.010	1.3	10/21/16 04:45	10/27/16	DJP	
6102412-06	Sample Location: #6 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	10/21/16 04:46	10/27/16	DJP	
Copper			0.184	mg/L	0.010	1.3	10/21/16 04:46	10/27/16	DJP	
6102412-07	Sample Location: #7 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	10/21/16 04:47	10/27/16	DJP	
Copper			0.184	mg/L	0.010	1.3	10/21/16 04:47	10/27/16	DJP	
6102412-08	Sample Location: #8 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	10/21/16 04:48	10/27/16	DJP	
Copper			0.180	mg/L	0.010	1.3	10/21/16 04:48	10/27/16	DJP	
6102412-09	Sample Location: #10 Drinking Fountain									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.
 This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6102412

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead		1030	ND	mg/L	0.002	0.02	10/21/16 04:50	10/27/16	DJP	
Copper			0.208	mg/L	0.010	1.3	10/21/16 04:50	10/27/16	DJP	
6102412-10	Sample Location: #11 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	10/21/16 04:51	10/27/16	DJP	
Copper			0.207	mg/L	0.010	1.3	10/21/16 04:51	10/27/16	DJP	
6102412-11	Sample Location: #12 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	10/21/16 04:52	10/27/16	DJP	
Copper			0.105	mg/L	0.010	1.3	10/21/16 04:52	10/27/16	DJP	
6102412-12	Sample Location: #13 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	10/21/16 04:53	10/27/16	DJP	
Copper			0.105	mg/L	0.010	1.3	10/21/16 04:53	10/27/16	DJP	
6102412-13	Sample Location: #14 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	10/21/16 04:56	10/27/16	DJP	
Copper			0.127	mg/L	0.010	1.3	10/21/16 04:56	10/27/16	DJP	
6102412-14	Sample Location: #15 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	10/21/16 04:57	10/27/16	DJP	
Copper			0.108	mg/L	0.010	1.3	10/21/16 04:57	10/27/16	DJP	
6102412-15	Sample Location: #16 Bottle Filler									
Lead		1030	ND	mg/L	0.002	0.02	10/21/16 04:59	10/27/16	DJP	
Copper			0.117	mg/L	0.010	1.3	10/21/16 04:59	10/27/16	DJP	
6102412-16	Sample Location: #17 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	10/21/16 05:00	10/27/16	DJP	
Copper			0.124	mg/L	0.010	1.3	10/21/16 05:00	10/27/16	DJP	
6102412-17	Sample Location: #18 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	10/21/16 05:02	10/27/16	DJP	
Copper			0.138	mg/L	0.010	1.3	10/21/16 05:02	10/27/16	DJP	
6102412-18	Sample Location: #19 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	10/21/16 05:03	10/27/16	DJP	
Copper			0.155	mg/L	0.010	1.3	10/21/16 05:03	10/27/16	DJP	
6102412-19	Sample Location: #20 Drinking Fountain									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6102412

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead		1030	ND	mg/L	0.002	0.02	10/21/16 05:04	10/27/16	DJP	
Copper			0.137	mg/L	0.010	1.3	10/21/16 05:04	10/27/16	DJP	
6102412-20	Sample Location: #21 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	10/21/16 05:05	10/27/16	DJP	
Copper			0.123	mg/L	0.010	1.3	10/21/16 05:05	10/27/16	DJP	
6102412-21	Sample Location: #23 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	10/21/16 05:08	10/27/16	DJP	
Copper			0.108	mg/L	0.010	1.3	10/21/16 05:08	10/27/16	DJP	
6102412-22	Sample Location: #24 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	10/21/16 05:09	10/27/16	DJP	
Copper			0.210	mg/L	0.010	1.3	10/21/16 05:09	10/27/16	DJP	
6102412-23	Sample Location: #25 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	10/21/16 05:12	10/27/16	DJP	
Copper			0.155	mg/L	0.010	1.3	10/21/16 05:12	10/27/16	DJP	
6102412-24	Sample Location: #26 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	10/21/16 05:13	10/27/16	DJP	
Copper			0.215	mg/L	0.010	1.3	10/21/16 05:13	10/27/16	DJP	
6102412-25	Sample Location: #28 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	10/21/16 05:19	10/27/16	DJP	
Copper			0.129	mg/L	0.010	1.3	10/21/16 05:19	10/27/16	DJP	
6102412-26	Sample Location: #29 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	10/21/16 05:20	10/27/16	DJP	
Copper			0.109	mg/L	0.010	1.3	10/21/16 05:20	10/27/16	DJP	
6102412-27	Sample Location: #30 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	10/21/16 05:22	10/27/16	DJP	
Copper			0.142	mg/L	0.010	1.3	10/21/16 05:22	10/27/16	DJP	
6102412-28	Sample Location: #31 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	10/21/16 05:22	10/27/16	DJP	
Copper			0.130	mg/L	0.010	1.3	10/21/16 05:22	10/27/16	DJP	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: <http://ChemLab.cc>
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6102412

Qualifiers and Definitions

DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the MRL (minimum reporting limit)
NA	Not Applicable
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
MRL	Minimum Reporting Limit
MDL	Minimum Detection Limit
MCL	Maximum Contamination Level
(‡)	ORELAP Accredited Analyte
(~)	Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

Tom Williams, Laboratory Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.