



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6092119

Bend LaPine Schools	Project: No Project	Date Reported: 10/05/16
1410 SE Wilson Ave.	Project #: Amity Creek	Date Received: 09/21/16 11:40
Bend, OR 97702	Client Contact: Mike Tiller	Sampled By: Jeff Kirkpatrick

Method: EPA 200.8								Matrix: Drinking Water		
	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
6092119-01	Sample Location: #1 Drinking Fountain									
Lead		1030	0.003	mg/L	0.002	0.02	09/15/16 04:23	09/29/16	DJP	
Copper			0.016	mg/L	0.010	1.3	09/15/16 04:23	09/29/16	DJP	
6092119-02	Sample Location: #2 Drinking Fountain									
Lead		1030	0.004	mg/L	0.002	0.02	09/15/16 04:24	09/29/16	DJP	
Copper			0.021	mg/L	0.010	1.3	09/15/16 04:24	09/29/16	DJP	
6092119-03	Sample Location: #3 Drinking Fountain									
Lead		1030	0.002	mg/L	0.002	0.02	09/15/16 04:27	09/29/16	DJP	
Copper			0.011	mg/L	0.010	1.3	09/15/16 04:27	09/29/16	DJP	
6092119-04	Sample Location: #4 Drinking Fountain									
Lead		1030	0.004	mg/L	0.002	0.02	09/15/16 04:29	09/29/16	DJP	
Copper			0.015	mg/L	0.010	1.3	09/15/16 04:29	09/29/16	DJP	
6092119-05	Sample Location: #5 Drinking Fountain									
Lead		1030	0.002	mg/L	0.002	0.02	09/15/16 04:33	09/29/16	DJP	
Copper			0.013	mg/L	0.010	1.3	09/15/16 04:33	09/29/16	DJP	
6092119-06	Sample Location: #6 Drinking Fountain									
Lead		1030	0.003	mg/L	0.002	0.02	09/15/16 04:35	09/29/16	DJP	
Copper			0.020	mg/L	0.010	1.3	09/15/16 04:35	09/29/16	DJP	
6092119-07	Sample Location: #7 Faucet									
Lead		1030	0.002	mg/L	0.002	0.02	09/15/16 04:37	09/29/16	DJP	
Copper			0.019	mg/L	0.010	1.3	09/15/16 04:37	09/29/16	DJP	
6092119-08	Sample Location: #8 Drinking Fountain									
Lead		1030	0.031	mg/L	0.002	0.02	09/15/16 04:40	09/29/16	DJP	CON-1
Copper			0.022	mg/L	0.010	1.3	09/15/16 04:40	09/29/16	DJP	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: <http://ChemLab.cc>
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6092119

Qualifiers and Definitions

CON-1	Results confirmed by duplicate analysis.
DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the MRL (minimum reporting limit)
NA	Not Applicable
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
MRL	Minimum Reporting Limit
MDL	Minimum Detection Limit
MCL	Maximum Contamination Level
(‡)	ORELAP Accredited Analyte
(~)	Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

Tom Williams, Laboratory Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.