



# UMPQUA Research Company

626 NE Division St. - P.O. Box 609  
 Myrtle Creek, Oregon 97457  
 (541) 863-5201 Fax: (541) 863-6199  
 E-mail: Lab@URCmail.net  
 Internet: http://ChemLab.cc  
 ORELAP ID# OR100031

## ANALYSIS REPORT

URC # 6101913

Bend LaPine Schools 1410 SE Wilson Ave. Bend, OR 97702	Project: 2016 Lead Testing Project #: Kingston-West Side Village Elementary Client Contact: Mike Tiller	Date Reported: 10/28/16 Date Received: 10/19/16 08:55 Sampled By: Jon Layton
--	--	--

Method: EPA 200.8

Matrix: Drinking Water

	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
6101913-01	Sample Location: #1 Drinking Fountain									
	Lead	1030	ND	mg/L	0.002	0.02	10/14/16 05:33	10/20/16	DJP	
	Copper		0.196	mg/L	0.010	1.3	10/14/16 05:33	10/20/16	DJP	
6101913-02	Sample Location: #2 Drinking Fountain									
	Lead	1030	0.002	mg/L	0.002	0.02	10/14/16 05:33	10/20/16	DJP	
	Copper		0.191	mg/L	0.010	1.3	10/14/16 05:33	10/20/16	DJP	
6101913-03	Sample Location: #3 Drinking Fountain									
	Lead	1030	ND	mg/L	0.002	0.02	10/14/16 05:38	10/20/16	DJP	
	Copper		0.191	mg/L	0.010	1.3	10/14/16 05:38	10/20/16	DJP	
6101913-04	Sample Location: #4 Drinking Fountain									
	Lead	1030	ND	mg/L	0.002	0.02	10/14/16 05:37	10/20/16	DJP	
	Copper		0.074	mg/L	0.010	1.3	10/14/16 05:37	10/20/16	DJP	
6101913-05	Sample Location: #5 Bottle Filler									
	Lead	1030	ND	mg/L	0.002	0.02	10/14/16 05:37	10/20/16	DJP	
	Copper		0.093	mg/L	0.010	1.3	10/14/16 05:37	10/20/16	DJP	
6101913-06	Sample Location: #6 Prep Sink									
	Lead	1030	ND	mg/L	0.002	0.02	10/14/16 05:41	10/20/16	DJP	
	Copper		0.118	mg/L	0.010	1.3	10/14/16 05:41	10/20/16	DJP	
6101913-07	Sample Location: #7 Prep Sink									
	Lead	1030	ND	mg/L	0.002	0.02	10/14/16 05:43	10/20/16	DJP	
	Copper		0.182	mg/L	0.010	1.3	10/14/16 05:43	10/20/16	DJP	
6101913-08	Sample Location: #8 Drinking Fountain									
	Lead	1030	ND	mg/L	0.002	0.02	10/14/16 05:45	10/20/16	DJP	
	Copper		0.192	mg/L	0.010	1.3	10/14/16 05:45	10/20/16	DJP	
6101913-09	Sample Location: #9 Drinking Fountain									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



# UMPQUA Research Company

626 NE Division St. - P.O. Box 609  
 Myrtle Creek, Oregon 97457  
 (541) 863-5201 Fax: (541) 863-6199  
 E-mail: Lab@URCmail.net  
 Internet: http://ChemLab.cc  
 ORELAP ID# OR100031

## ANALYSIS REPORT

URC # 6101913

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead		1030	ND	mg/L	0.002	0.02	10/14/16 05:45	10/20/16	DJP	
Copper			0.188	mg/L	0.010	1.3	10/14/16 05:45	10/20/16	DJP	
6101913-10	Sample Location: #10 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	10/14/16 05:47	10/20/16	DJP	
Copper			0.221	mg/L	0.010	1.3	10/14/16 05:47	10/20/16	DJP	
6101913-11	Sample Location: #11 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	10/14/16 05:47	10/20/16	DJP	
Copper			0.198	mg/L	0.010	1.3	10/14/16 05:47	10/20/16	DJP	
6101913-12	Sample Location: #12 Drinking Fountain									
Lead		1030	0.009	mg/L	0.002	0.02	10/14/16 05:51	10/20/16	DJP	
Copper			0.289	mg/L	0.010	1.3	10/14/16 05:51	10/20/16	DJP	
6101913-13	Sample Location: #13 Drinking Fountain									
Lead		1030	0.002	mg/L	0.002	0.02	10/14/16 05:53	10/20/16	DJP	
Copper			0.222	mg/L	0.010	1.3	10/14/16 05:53	10/20/16	DJP	
6101913-14	Sample Location: #14 Drinking Fountain									
Lead		1030	0.002	mg/L	0.002	0.02	10/14/16 05:53	10/20/16	DJP	
Copper			0.198	mg/L	0.010	1.3	10/14/16 05:53	10/20/16	DJP	
6101913-15	Sample Location: #15 Drinking Fountain									
Lead		1030	0.004	mg/L	0.002	0.02	10/14/16 05:59	10/20/16	DJP	
Copper			0.184	mg/L	0.010	1.3	10/14/16 05:59	10/20/16	DJP	
6101913-16	Sample Location: #16 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	10/14/16 05:59	10/20/16	DJP	
Copper			0.179	mg/L	0.010	1.3	10/14/16 05:59	10/20/16	DJP	
6101913-17	Sample Location: #17 Drinking Fountain									
Lead		1030	0.002	mg/L	0.002	0.02	10/14/16 06:00	10/20/16	DJP	
Copper			0.167	mg/L	0.010	1.3	10/14/16 06:00	10/20/16	DJP	
6101913-18	Sample Location: #18 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	10/14/16 06:02	10/20/16	DJP	
Copper			0.229	mg/L	0.010	1.3	10/14/16 06:02	10/20/16	DJP	
6101913-19	Sample Location: #19 Drinking Fountain									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



**UMPQUA Research Company**

626 NE Division St. - P.O. Box 609  
Myrtle Creek, Oregon 97457  
(541) 863-5201 Fax: (541) 863-6199  
E-mail: Lab@URCmail.net  
Internet: http://ChemLab.cc  
ORELAP ID# OR100031

**ANALYSIS REPORT**

**URC # 6101913**

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead		1030	ND	mg/L	0.002	0.02	10/14/16 06:02	10/20/16	DJP	
Copper			0.248	mg/L	0.010	1.3	10/14/16 06:02	10/20/16	DJP	
6101913-20	Sample Location: #20 Drinking Fountain									
Lead		1030	0.002	mg/L	0.002	0.02	10/14/16 06:05	10/20/16	DJP	
Copper			0.226	mg/L	0.010	1.3	10/14/16 06:05	10/20/16	DJP	
6101913-21	Sample Location: #21 Drinking Fountain									
Lead		1030	0.002	mg/L	0.002	0.02	10/14/16 06:05	10/20/16	DJP	
Copper			0.195	mg/L	0.010	1.3	10/14/16 06:05	10/20/16	DJP	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



## UMPQUA Research Company

626 NE Division St. - P.O. Box 609  
Myrtle Creek, Oregon 97457  
(541) 863-5201 Fax: (541) 863-6199  
E-mail: Lab@URCmail.net  
Internet: <http://ChemLab.cc>  
ORELAP ID# OR100031

## ANALYSIS REPORT

URC # 6101913

### Qualifiers and Definitions

DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the MRL (minimum reporting limit)
NA	Not Applicable
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
MRL	Minimum Reporting Limit
MDL	Minimum Detection Limit
MCL	Maximum Contamination Level
(‡)	ORELAP Accredited Analyte
(~)	Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

Tom Williams, Laboratory Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.